


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction 1/4cne 1/4ne 1/4	Section number 20	Township number T 26 S R 15W E/W	Range number
2. Distance and direction from nearest town or city: 2s 3/4e		3. Owner of well: Gabbert-Jones Inc			
Street address of well location if in city: Hopewell Ks.		R.R. or street: 830 Sutton Pl			
		City, state, zip code: Wichita, Ks. 67202			
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 8 in. Completion date 4-5-78 Well depth 77 ft.	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material <input type="checkbox"/> Height: Above or Below <input checked="" type="checkbox"/> <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 77 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; Gauge No. sch 40	
5. Type and color of material		From	To	10. Screen: Manufacturer's name Jetstream	
				Type pvc Dia. 5"	
				Slot/gauze 1/32" Length 20'	
				Set between 57 ft. and 77 ft.	
				Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"	
				11. Static water level: 24 ft. below land surface Date 4-5-78 mo./day/yr.	
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 60 g.p.m.	
				13. Water sample submitted: ____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date ____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 50 Direction s Type test oil Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name R2 Great Bend Ks License No. _____ Address _____ Signed Kelly Price Date 9-19-79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
Sec
1/4
1/4
1/4
CNE NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5