

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction 1/4 C 1/4 NW 4	Section number 30	Township number T 26 S R 15 E/W	Range number
2. Distance and direction from nearest town or city: 3 South of Hopewell 1/2 West south into field			3. Owner of well: Ralph Bisel R.R. or street: Macksville, Ks. 67557 City, state, zip code:			
4. Locate with "X" in section below: Sketch map: N W E S 1 Mile 1 Mile			6. Bore hole dia. 29 in. Completion date _____ Well depth 180 ft. 12-3-76			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Top Soil Sandy			9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 180 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7 ga.			
			10. Screen: Manufacturer's name Doerr's Type steel Dia. 16 Slot/gauze 3/16 Length 60 Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8			
Brown Clay			11. Static water level: 16 ft. below land surface Date 12-3-76 mg./day/yr.			
Gray Clay with Fine Sand			12. Pumping level below land surfaces: 21 ft. after 1 hrs. pumping 800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.			
Gray & White Clay			13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 12-3-76 mg./day/yr.			
Sand & Gravel			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade			
Brown & White Clay with Some Sand & Gravel Fine			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
Sand & Gravel			16. Nearest source of possible contamination: ft. 400 Direction NE Type septic tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
(Use a second sheet if needed)			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Roller Model number 5BHC12 HP 80 Volts _____ Length of drop pipe 90 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, Ks. Signed Fredia Dodson Date 3/23/77 Authorized representative			
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

26
15
30
1/4
1/4
1/4
C NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5