


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction ne 1/4 nw 1/4 nw 1/4	Section number 9	Township number T 26 S R 16	Range number 16	EW
2. Distance and direction from nearest town or city: 1/2 S 1/4 E from Trousdale, Ks. Street address of well location if in city:				3. Owner of well: Roger Parker R.R. or street: none City, state, zip code: Haviland, Kansas 67059			
4. Locote with "X" in section below: <div style="text-align: center;">  </div> Sketch map:				6. Bore hole dia. 10 in. Completion date _____ Well depth 75 ft. 5-12-79			
5. Type and color of material				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Water Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
From To				9. Casing: Material pvc Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 6-5/8 to 75 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. .280			
				10. Screen: Manufacturer's name _____ CertainTeed Type pvc Dia. _____ Slot xxx 1/16 Length 20 Set between 55 ft. and 75 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8			
sandy top soil				11. Static water level: _____ mo./day/yr. 31 ft. below land surface Date 5-12-79			
clay				12. Pumping level below land surfaces: 31 ft. after 1 hrs. pumping 100 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 200 g.p.m.			
sand & gravel				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 5-12-79			
clay				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade			
good clean sand & gravel				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
(Use a second sheet if needed)				16. Nearest source of possible contamination: ft. 200 Direction se Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrattz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed Jandys Lopez Date 5-15-79 Authorized representative			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley							

T
R
Sec
26
16
09
NE NW NW
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5