

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 10	Township number T 26 S R 16 X W	Range number
2. Distance and direction from nearest town or city: 1 mi. So. 1 mi. E. of Trousdale, Kansas Street address of well location if in city:			3. Owner of well: B & N Drilling Co. R.R. or street: Box 846 City, state, zip code: Independence, Kansas 67301			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia 9 7/8 in. Completion date _____ Well depth 90 ft. 4-4-78		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy top soil		0	1/2	9. Casing: Material pvc Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 4 1/2 in. to 90 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 237		
Clay		1/2	5	10. Screen: Manufacturer's name CertainTeed Type pvc Dia. 4 1/2 Slot <input checked="" type="checkbox"/> 1/32 Length 20 Set between 70 ft. and 90 ft. _____ ft. and _____ ft.		
Gravel		5	30	Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8		
Clay		30	38	11. Static water level: _____ mo./day/yr. 15 ft. below land surface Date 4-4-78		
Good sand & gravel		38	90	12. Pumping level below land surfaces: 15 ft. after 1 hrs. pumping 100 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 300 g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 108 Direction East Type oil well Well disinfected upon completion? HTH Yes <input type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: _____ Not installed Manufacturer's name Customer pump Model number _____ HP 5 Volts 230 Length of drop pipe 42 ft. capacity 120 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Kansas 67530 Signed Sandy Tulgar Date 4-6-78 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

T
R
W
E
Sec
10
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5