


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction 1/4 c 1/4 se 1/4	Section number 11	Township number T 26 S R 16	Range number 16
2. Distance and direction from nearest town or city: 1/2-S 3-E 3/4-S west side from Trousdale, Ks. Street address of well location if in city:				3. Owner of well: Galen Schultz R.R. or street: 9921 W. 65 Place City, state, zip code: Merriam, Ks. 67203		
4. Locate with "X" in section below: Sketch map: 				6. Bore hole dia. 29 in. Completion date _____ Well depth 120 ft. 5-28-78		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material steel Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 120 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7		
				10. Screen: Manufacturer's name _____ Doerrs Type steel Dia. _____ Slot 3/16 3/16 Length 52 Set between 68 ft. and 120 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8		
				11. Static water level: _____ mo./day/yr. 17 ft. below land surface Date 3-8-76		
				12. Pumping level below land surfaces: 34 ft. after 1 hrs. pumping 700 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400+ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 3-8-76		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 2200 Direction SW Type gaswell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name W.L.R. Model number 3-12MS HP 50 Volts 460 Length of drop pipe 70 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed S. Kilgore 4-6-79 Authorized representative		
18. Elevation: 2065		19. Remarks: 27859 26 16 11 NDX				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

26 16 11 NDX
Sec 11 1/4 16 1/4