


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction 1/4 c 1/4 ne 1/4	Section number 15	Township number T 26 S R 16 E 0	Range number
2. Distance and direction from nearest town or city: 1 1/2-S 1 3/4-E south side from Trousdale, Ks. Street address of well location if in city:			3. Owner of well: Ron Schultz R.R. or street: none City, state, zip code: Trousdale, Ks. 67145			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 29 in. Completion date _____ Well depth 100 ft. 5-28-76			
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
top soil			0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
brown & gray clay			2	17	9. Casing: Material steel Height: Above or below _____ Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 100 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 7	
sand & gravel clean med. loose			17	30	10. Screen: Manufacturer's name _____ Doerrs Type steel Dia. _____ Slot size 3/16 Length 40 Set between 60 ft. and 100 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8	
fine sand & sandy clay			30	35	11. Static water level: _____ mo./day/yr. 10 ft. below land surface Date 5-31-73	
sand & gravel clean coarse loose			35	94	12. Pumping level below land surfaces: 26 ft. after 1 hrs. pumping 700 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400 g.p.m.	
brown clay			94	100	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 5-31-73	
					14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
					15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: ft. 4 mi Direction nw Type gaswell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: Not installed Manufacturer's name W.I.R. Model number 3-12MS HP 50 Volts 460 Length of drop pipe 70 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					(Use a second sheet if needed)	
18. Elevation: 2070		19. Remarks: 27860 26 16 15 MAX			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed S. K. Goode Date 5/27/73 Authorized representative	

26-16-15
Sec 15
1/4 1/4 NE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5