USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Edwards	SE 1/4 SE 1/4 SE 1/4	8	T 26 S	R 17 E/W

2. Distance and direction from nearest town or city: 1mi west 1mi South of Fellsburg, Ks.
Street address of well location if in city:

3. Owner of well: Jake Roenbaugh
R.R. or street: none
City, state, zip code: Lewis, Ks. 67552

4. Locate with "X" in section below: Sketch map:

N / NW / NE / W / E / SW / SE / S / 1 Mile / 1 Mile — X

6. Bore hole dia. 9 7/8 in. Completion date _____
Well depth 70 ft. 1-18-78

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Materiol PVC Height: Above or ~~below~~
Threaded ____ Welded ____ Surface 24 in.
RMP ____ PVC X Weight ____ lbs./ft.
Dia. 4 1/2 in. to 70 ft. depth Wall Thickness: inches or
Dia. ____ in. to ____ ft. depth gage No. .237

5. Type and color of material	From	To
Top soil	0	2
Fine sand & clay	2	16
Clay	16	27
Fine sand & clay	27	33
Sand & gravel	33	42
Clay	42	49
Sand & gravel	49	54
Clay with Little gravel mixed	54	59
Sand & gravel	59	70

(Use a second sheet if needed)

10. Screen: Manufacturer's name CertainTeed
Type PVC Dia. 4 1/2
Slot/gauze 1/116 Length 20'
Set between 50 ft. and 70 ft.
____ ft. and ____ ft.
Gravel pack? X Size range of material 1/2 3/8 3/4

11. Static water level: mo./day/yr.
46 1/2 ft. below land surface Date 1-18-78

12. Pumping level below land surfaces: NA.
____ ft. after ____ hrs. pumping ____ g.p.m.
____ ft. after ____ hrs. pumping ____ g.p.m.
Estimated maximum yield ____ g.p.m.

13. Water sample submitted: mo./day/yr.
X Yes ____ No Date 1-18-78

14. Well head completion:
____ Pitless adapter ____ Inches above grade

15. Well grouted? X
With: X Neat cement ____ Bentonite ____ Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 1/4 mi Direction west Type septic
Well disinfected upon completion? ~~X~~ Yes ____ No

17. Pump: X Not installed
Manufacturer's name ____
Model number ____ HP ____ Volts ____
Length of drop pipe ____ ft. capacity ____ g.p.m.
Type:
____ Submersible ____ Turbine
____ Jet ____ Reciprocating
____ Centrifugal ____ Other

T 26 R 17 (E/W) Sec 8 1/4 1/4 1/4 SE SE SE

18. Elevation:

Topography:
X Hill
____ Slope
____ Upland
____ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Business name Rosencrantz-Bemis License No. 134
Address Great Bend, Ks. 67530
Signed Sandy Kilgore Date 2-27-78
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

M1-1023