

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Edwards		Fraction $\frac{1}{4}$ ^C $\frac{1}{4}$ SW $\frac{1}{4}$		Section number 11		Township number T 26 S R 17 E/W		Range number	
2. Distance and direction from nearest town or city: 1 E 1 S				3. Owner of well: header lightcap					
Street address of well location if in city: Fellsburg, KS				R.R. or street: Offerle, KS					
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 30 in. Completion date 2-17-77 Well depth 90 ft.					
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
5. Type and color of material				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 50 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 3/16"					
				10. Screen: Manufacturer's name Doerr Type steel Dia. 16 Slot/gauze 1/8" Length 40' Set between 50 ft. and 90 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"					
				11. Static water level: <input type="checkbox"/> mo./day/yr. 21 ft. below land surface Date 2-17-77					
				12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. 45 ft. after 4 hrs. pumping 1000 g.p.m. Estimated maximum yield 1200 g.p.m.					
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>					
				14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade					
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.					
				16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds Model number 4125 HP 30 Volts <input type="checkbox"/> Length of drop pipe 80 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kelly's Waterwell ser 186 Business name K 2 Great Bend, KS License No. <input type="checkbox"/> Address Kelly Dnee Date 4-20-77 Signed Kelly Dnee Authorized representative					
18. Elevation:		19. Remarks:							
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley									

T 26
 R 17
 Sec 11
 1/4
 1/4
 1/4
 1/4