

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

*Feeder #1*

1. Location of well:	County <u>Edwards</u>	Fraction <u>C-SW</u> 1/4 1/4 1/4	Section number <u>16</u>	Township number <u>26S</u> T S R	Range number <u>17W</u> E/W
2. Distance and direction from nearest town or city: <u>1 1/2 mi SW</u> Street address of well location if in city: <u>2 1/2 south Felshung</u>			3. Owner of well: <u>Dupont Gardner</u> R.R. or street: <u>Wichita Kansas</u> City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. <u>8</u> in. Completion date <u>8-16-77</u> Well depth <u>60</u> ft. 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <u>Plastic</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>2 1/2</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>200</u> lbs./ft. Dia. <u>5</u> in. to <u>60</u> ft. depth Wall Thickness: inches or Dia. <u>5</u> in. to <u>60</u> ft. depth gage No. <u>200</u>		
5. Type and color of material			From	To	
<u>Clay</u>			<u>0</u>	<u>10</u>	10. Screen Manufacturer's name <u>Self Made</u>
<u>Sandy Clay</u>			<u>10</u>	<u>30</u>	Type <u>PVC</u> Dia. <u>5</u>
<u>Sand</u>			<u>30</u>	<u>40</u>	Slot gauge <u>8</u> Length <u>20</u>
<u>Gravel</u>			<u>40</u>	<u>60</u>	Set between <u>40</u> ft. and <u>60</u> ft.
					Gravel pack? <u>yes</u> Size range of material <u>5-1/4</u>
					11. Static water level: <u>22</u> ft. below land surface Date <u>8-16-77</u>
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
					13. Water sample submitted: ____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date ____
					14. Well head completion: ____ Pitless adapter ____ Inches above grade
					15. Well grouted? <u>yes</u> With: ____ Neat cement <input checked="" type="checkbox"/> Bentonite ____ Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: ft. ____ Direction ____ Type ____ Well disinfected upon completion? ____ Yes ____ No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Myers Water Well</u> Business name <u>Myers Water Well</u> License No. <u>CS143</u> Address <u>143</u> Signed <u>R. Myers</u> Date <u>8-16-77</u> Authorized representative
18. Elevation:			19. Remarks:		
Topography: ____ Hill <input checked="" type="checkbox"/> Slope ____ Upland ____ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5