

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Edwards</b>	Fraction <b>1/4 c 1/4 se 1/4</b>	Section number <b>18</b>	Township number <b>26</b>	Range number <b>17</b>	<b>X</b> <b>W</b>
2. Distance and direction from nearest town or city: <b>from Fellsburg 3 1/2 mi. n. w.</b> Street address of well location if in city: <b>24-5 24-W</b>				3. Owner of well: <b>Earl McBride</b> R.R. or street: <b>Lewis, Ks. 67552</b> City, state, zip code:			
4. Locate with "X" in section below:  N W E S 1 Mile			Sketch map: <b>North side</b>		6. Bore hole dia. <b>29</b> in. Completion date <b>4-5-75</b> Well depth <b>158</b> ft.		
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Sandy top soil			0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy brown clay			2	6	9. Casing: Material <b>steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <input checked="" type="checkbox"/> <b>24</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.		
Sand and gravel little clay			6	25	Dia. <b>16</b> in. to <b>158</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>7</b>		
Sand and gravel clean coarse loose			25	35	10. Screen: Manufacturer's name <b>Doerra</b> Type <b>steel</b> Dia. <b>16</b> Slot/gage <b>3/16</b> Length <b>80</b> Set between <b>78</b> ft. and <b>158</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>3/4-3/8-1/2</b>		
Brown & white clay			35	43	11. Static water level: <input type="checkbox"/> mo./day/yr. <b>23 1/2</b> ft. below land surface Date <b>4-22-74</b>		
Sand and gravel clean coarse loose			43	67	12. Pumping level below land surfaces: <b>36</b> ft. after <b>1</b> hrs. pumping <b>800</b> g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <b>1400</b> g.p.m.		
Brown & white clay with whiterock			67	76	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <b>4-22-74</b>		
Sand and gravel coarse loose			76	88	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
Sand and gravel, loose, clean & medium			88	105	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.		
Brown & white clay with sand and gravel			105	107 1/2	16. Nearest source of possible contamination: ft. <b>5 3/4</b> mile <b>north</b> type <b>septic tank</b>		
white rock w/ brown & white clay			115	121	Well disinfected upon completion? <b>hth</b> Yes <input type="checkbox"/> No <input type="checkbox"/>		
Fine sand lot of clay			121	125	17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>W.L.R.</b> Model number <b>5-12chc</b> HP <b>80</b> Volts <b>____</b> Length of drop pipe <b>60</b> ft. capacity <b>800</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand and gravel clean coarse loose			125	149	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Rosencrantz-Bemis 134</b> Business name <b>Great Bend, Ks.</b> License No. <b>30</b> Address <b>____</b> Signed <b>S. R. Igore</b> Date <b>6-19-79</b> Authorized representative		
18. Elevation:		19. Remarks: <b>gray clay</b>		165	172		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5