## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County Fraction			Section number		Township number Range number
1. Location of well:	doluganda	1/4 C 1/4 NE	1/4	1	9	1 26 s R 17 E/W
2. Distance and dire	ction from nearest town or city:  W. 4 S. 4 W. 6 I location if in city:	Y Fellowanks	3. Owr	ner of well		Earl McBride
Street address or well	l location if in city:	0	City, s	tate, zip	code:	Lewis, Ks. 67552
4. Locate with "X" i		Sketch map:				6. Bore hole dia. 29 in. Completion date
NW	*					7 Cable toolXRotary Driven Dug Hollow rod Jetted Bored Reverse rotary
W 1 1 E						8. Use:Domestic Public supply IndustryXIrrigotion Air conditioning Stock
sw   se						9. Casing: Material Steeheight: Above or below
<u>†                                      </u>					Threoded Welded Surface in	
1 Mile ————————————————————————————————————				F	7	Dia.16 in. to 168 t. depth Wall Thickness; inches or Dia in. to ft. depth gage No 7 88
5. Type and color of	marenai			From	То	10. Screen: Manufacturer's name
Sandy top soil				0	2	Type steel Dia. 16
Brown clay				2	7	Slot/gauze 3/16 Length 80 Set between 88 ft. and 168 ft.
Sand and gravel				7	26	Gravel pack? X Size range of material 3/4-5/8-
Brown	clay			26	30	11. Static water level: mo./day/yr. 20 ft. below land surface Date 3-3-77
Sand and clay mixed				30	40	12. Pumping level below land surfaces:  31 ft. after 1 hrs. pumping 800 g.p.m.
Sand andgravel				40	58	1
Brown and white clay			<del> </del>	58	72	
Sandan	d gravel clean	coarse loose		72	100	14. Well head completion:
Brown and white clay				100	109	Pitless adapter Inches above grade  15. Well grouted? X
Hard rock				109	110	lund in a large a little
White clay				110	117	
Sand and gravel clean, coarse, loose			se	117	169	Well disinfected upon completion?YesNo
Brown clay				169	170	17. Pump:  Manufacturer's name  Not installed  R.
						Madel number 5-12 BHG Volts Length of drop pipe 90 ft. capacity 800.p.m.
						Type:  Submersible X Turbine
(Use a second sheet if needed)						Jet Reciprocating Centrifugal Other
18. Elevation:	19. Remarks:	in includes)				20. Water well contractor's certification:
					This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
Topography:					Rosencrantz-Bemis 134	
—HillSlope						Business name Great Bend, Ks. 6754
Upland Valley						Signed Authorized representative Date 5-19-77
		511 11 15 15 1				4