

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Edwards</u>	Fraction <u>1/4 C 1/4 NW 4</u>	Section number <u>20</u>	Township number <u>T 26</u>	Range number <u>S 17 E/W</u>	
2. Distance and direction from nearest town or city: <u>2 1/2 So. 1 3/4 W. 1/4 So. of Tellerburg</u> Street address of well location if in city: <u>Ks</u>			3. Owner of well: <u>Earl McBride</u> R.R. or street: <u>Lewis, Ks. 67552</u> City, state, zip code:				
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile		Sketch map: 		6. Bore hole dia. <u>29</u> in. Completion date <u>4-21-77</u> Well depth <u>186</u> ft.			
5. Type and color of material		From		To		7. <u>X</u> Cable tool <u>X</u> Rotary <u> </u> Driven <u> </u> Dug <u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u> </u> Reverse rotary	
						8. Use: <u> </u> Domestic <u> </u> Public supply <u> </u> Industry <u>X</u> Irrigation <u> </u> Air conditioning <u> </u> Stock <u> </u> Lawn <u> </u> Oil field water <u> </u> Other	
						9. Casing: Material <u>steel</u> Height: Above or below Threaded <u> </u> Welded <u>X</u> Surface <u>18</u> in. RMP <u> </u> PVC <u> </u> Weight <u> </u> lbs./ft. Dia. <u>16</u> in. to <u>186</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth Gauge No. <u>7 58</u>	
						10. Screen: Manufacturer's name <u>Doerra</u> Type <u>steel</u> Dia. <u>16</u> Slot/gauze <u>3/16</u> Length <u>60</u> Set between <u>126</u> ft. and <u>186</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>X</u> Size range of material <u>3/4-3/8</u>	
						11. Static water level: <u>15</u> mo./day/yr. <u>15</u> ft. below land surface Date <u>3-23-77</u>	
18. Elevation: <u>2143</u> Topography: <u>X</u> Hill <u> </u> Slope <u> </u> Upland <u> </u> Valley		19. Remarks:		12. Pumping level below land surfaces: <u>34</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1400</u> g.p.m.			
				13. Water sample submitted: <u> </u> mo./day/yr. <u>X</u> Yes <u> </u> No Date <u>3-23-77</u>			
				14. Well head completion: <u> </u> Pitless adapter <u> </u> Inches above grade			
				15. Well grouted? <u>X</u> With: <u> </u> Neat cement <u> </u> Bentonite <u>X</u> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.			
				16. Nearest source of possible contamination: <u>corral</u> <u>22m</u> Direction <u>W</u> Type <u>septic</u> Well disinfected upon completion? <u>X</u> Yes <u> </u> No			
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosencrantz-Bemis 134</u> Business name <u>Great Bend, Ks. 67552</u> License No. <u> </u> Address <u> </u> Signed <u>Sanford H. Lane</u> Date <u>5-19-77</u> Authorized representative		17. Pump: <u> </u> Not installed Manufacturer's name <u>W.T.R.</u> Model number <u>4-12 BH 60</u> Volts <u> </u> Length of drop pipe <u>90</u> ft. capacity <u>800</u> g.p.m. Type: <u> </u> Submersible <u>X</u> Turbine <u> </u> Jet <u> </u> Reciprocating <u> </u> Centrifugal <u> </u> Other					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5