


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction 1/4 1/4 1/4	Section number 26	Township number T 26 S	Range number R 17W E/W
2. Distance and direction from nearest town or city: 3 1/2 s 1 1/4 e Street address of well location if in city: Fellsburg, Ks.			3. Owner of well: Damac Drlg Inc R.R. or street: Box 1164 City, state, zip code: Great Bend, Ks.			
4. Locote with "X" in section below: Sketch map: 			6. Bore hole dia. 8 in. Completion date 12-21-77 Well depth 60 ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <input type="checkbox"/> Height: Above XXXX Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.8 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches 40 Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. sch 40			
			10. Screen: Manufacturer's name Jetstream Type pvc Dia. 5" Slot/gauze 1/32" Length 20' Set between 40 ft. and 60 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8-3/4"			
			11. Static water level: 12 ft. below land surface Date 12-22-77 mo./day/yr.			
(Use a second sheet if needed)			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 60 g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. ____ Yes <input checked="" type="checkbox"/> No Date ____			
			14. Well head completion: ____ Pitless adapter 12 Inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> With: ____ Neat cement <input checked="" type="checkbox"/> Bentonite ____ Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: oil test ft. 55 Direction n Type ____ Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Kellys Waterwell Ser 186 Business name License No. Address R2 Great Bend, Ks. Signed Kelly Price Date 8-22-79 Authorized representative			
			19. Remarks:			
			19. Remarks:			
			19. Remarks:			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5