

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Edwards		County: Edwards		Fraction: 1/4 1/4 NE 1/4		Section number: 31		Township number: T 26 S		Range number: R 17		XW	
2. Distance and direction from nearest town or city: 4 1/2 Mi. East & 9 1/4 Mi. North of Greensburg, Ks.						3. Owner of well: Mr. Ron Hoener R.R. or street: Circle 8 Land Company City, state, zip code: Iuka, Kansas 67066							
4. Locate with "X" in section below: Well No. 3						6. Bore hole dia. 30 in. Completion date 2/9/77 Well depth 143 ft.							
						7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary							
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other							
						9. Casing: Material Steel Height: Above ground 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 34.25 lbs./ft. Dia. 16 in. to 91 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.203							
5. Type and color of material						From		To		10. Screen: Manufacturer's name Doerr Type Steel Dia. 16 Slot/gauze 1/8" Length 52 Set between 91 ft. and 143 ft. Gravel pack? yes Size range of material 1/4 - 1/8			
Sandy soil						0		2		11. Static water level: 24.0 ft. below land surface Date 11/19/76			
Brown silt w/clay lenses						2		45		12. Pumping level below land surfaces: No Test ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield 1200 g.p.m.			
Med. to coarse sand & gravel						45		70		13. Water sample submitted: ____ Yes <input checked="" type="checkbox"/> No Date ____			
Brown clay						70		75		14. Well head completion: 12 inches above grade <input type="checkbox"/> Pitless adapter			
Med. to coarse sand & gravel						75		143		15. Well grouted yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
Gray clay						143				16. Nearest source of possible contamination: Farm ft. 1300 Direction North Type Farm Well disinfected upon completion? ____ Yes <input checked="" type="checkbox"/> No			
										17. Pump: Not installed Manufacturer's name Layne WellLine Model number 12KH HP 100 Volts ____ Length of drop pipe 100 ft. capacity 1200 g.p.m. Type: ____ Submersible <input checked="" type="checkbox"/> Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other			
(Use a second sheet if needed)										18. Elevation:			
										19. Remarks:			
										20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name Wichita, Kansas License No. ____ Address Wichita, Kansas Date 2/23/77 Signed [Signature] Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5