



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County EDWARDS	Fraction NW 1/4 SE 1/4 SE 1/4	Section number 5	Township number T 26 S R 18 E/W	Range number
2. Distance and direction from nearest town or city: 7 S 2 1/2 W 3/4 S 1/4 W of Lawler			3. Owner of well: RAY DILLON JR. R.R. or street: 201 KISINA PARKWAY City, state, zip code: HUTCHINSON KANSAS 67501		
4. Locate with "X" in section below: 			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 27 in. Completion date 1-20-76 Well depth 82 ft.
Sandy soil			0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Brown Clay			3	33	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Red. Sand			33	50	9. Casing: Material transite Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 1 FT in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30 lbs./ft. Dia. 16 in. to 56 ft. depth Wall Thickness: inches or Dia. 16 in. to 56 ft. depth gage No. 34
Brown Clay			50	51	10. Screen: Manufacturer's name transite Type slotted Dia. 16 Slot/gauge 3/16 Length 26 Set between 56 ft. and 82 ft. ft. and 82 ft. Gravel pack? Y Size range of material Y
Red. Good Gravel			51	66	11. Static water level: 27 ft. below land surface Date 12-15-75
Brown Clay			66	68	12. Pumping level below land surfaces: 48 ft. after 1 hr. pumping 1000 g.p.m. 44 ft. after 1/2 hrs. pumping 800 g.p.m. Estimated maximum yield 1200 g.p.m.
Red Gravel			68	71	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date OCT. 23, 1975
Brown Clay			71	73	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
Red. Good Gravel			73	80	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
White Clay			80	106	16. Nearest source of possible contamination: ft. 3 miles Direction south Type oil well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
ENGINE. 390 IHC 6' x 8' CONCRETE PLATFORM 8"					17. Pump: Manufacturer's name Western Foundry Not installed Model number 12 C.M. HP 64 Volts Length of drop pipe 100 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
TO PIVOT.					18. Elevation:
(Use a second sheet if needed)					19. Remarks: WATER SAMPLE CHLORIDES. 41 PPM
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Darrell Drilling Co 189 Business name Darrell Drilling Co License No. 189 Address 210 W. 4th St. Hutchinson Signed Darrell Drilling Date 1-16-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5