


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Edwards	Township name	Fraction C/NE$\frac{1}{4}$	Section number 22	Town number 26	Range number 18
Distance and direction from nearest town or city: 2$\frac{1}{2}$ miles South of Centerview $\frac{1}{4}$ West Street address of well location if in city:				3 Owner of well: Earnest Swisher Greensburg, Kansas Address:		
Locate with "X" in section below: N  W E S 1 Mile				Sketch map:		
2				4 Well depth: 172 ft. Date of completion 1-20-75 Well diameter 7 7/8		
Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input checked="" type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material pvc height: above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight 160 lbs./ft. 4 in. to 140 depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth		
				8 Screen: Manufacturer R & H Type pvc Dia. 4 Slot/gauze 1/16 Length 25 Set between 140 ft. and 165 ft. Fittings: 3/4-3/8-1/16 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material cb3		
				9 Static water level: 23 ft. below land surface Date 1-20-75		
				10 Pumping level below land surfaces: Not pumped ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
				11 Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 1-21-75		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: old corrall ft. 1500 Direction SW Type corrall Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Yellow brown gray clay 165 172				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. Signed Fredia Bosson Date 1-22-75 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						