

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County EDWARDS	Fraction SW 1/4 1/4 1/4	Section number 32	Township number T 26 S R 18 E/W	Range number 18
2. Distance and direction from nearest town or city: Street address of well location if in city: NE Greensburg			3. Owner of well: DAN SCHROEDER R.R. or street: City, state, zip code:			
4. Locate with "X" in section below:		Sketch map: 		6. Bore hole dia. 2 1/2" in. Completion date 5-8-76 Well depth 171 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				<input checked="" type="checkbox"/> Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface _____ in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 1 1/2 in. to 171 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____		
				10. Screen: Manufacturer's name DAERR Type SOT Dia. 1 1/2" Slot/gauze 1 9/16 Length 20' Set between 151 ft. and 171 ft. _____ ft. and _____ ft. Gravel pack? YES Size range of material 4/4		
				11. Static water level: _____ mo./day/yr. 29 ft. below land surface Date 5-9-76		
				12. Pumping level below land surfaces: 38 ft. after 2 1/2 hrs. pumping 820 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name NATIONAL Model number _____ HP _____ Volts _____ Length of drop pipe 120 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation: 2145		19. Remarks: 25814 26 18 32 NCX		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. O.B. Adams Drilling 292 Business name _____ License No. _____ Address West Hwy 50 Signed O.B. Adams Date 7-26-76 Authorized representative		

26 18 32
 W
 Sec 32
 1/4 1/4 1/4
 CSK