



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>Edwards</u>	Township name <u>South Brown</u> <u>E1</u>	Fraction <u>SW 1/4</u>	Section number <u>24</u>	Town number <u>26</u>	Range number <u>18</u>
Distance and direction from nearest town or city: <u>6 mi. south, 1 mi. west of Centerview, Kans.</u> Street address of well location if in city:				3 Owner of well: <u>Harold Newsom</u> <u>Lewis, Kansas</u> Address: <u>67552</u>		
Locate with "X" in section below: N  W S 1 Mile		Sketch map: 		4 Well depth: <u>104</u> ft. Date of completion <u>5/19/75</u> Well diameter <u>28</u> in.		
2 Type and color of material		From To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
				7 Casing: Material <u>trans</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. Weight <u>38</u> lbs./ft. to <u>65</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth		
				8 Screen: Manufacturer <u>Johnson</u> Type <u>slot</u> Dia. <u>16</u> Slot/gauze <u>3/16</u> Length <u>39</u> Set between <u>6.5</u> ft. and <u>104</u> ft. Fittings: <u>18-1/4</u> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
				9 Static water level: <u>24</u> ft. below land surface Date <u>5-19-75</u>		
(use a second sheet if needed)				10 Pumping level below land surfaces: <u>1008</u> ft. after <u>1</u> hrs. pumping <u>53</u> g.p.m. <u>800</u> ft. after <u>1/2</u> hrs. pumping <u>49</u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> 2 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>6</u> ft. to <u>10</u> ft.		
				14 Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Jacuzzi</u> Model number <u>4-1275</u> HP <u>1</u> Volts <u>115</u> Length of drop pipe <u>60</u> ft. capacity <u>300</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Darling Drilling Co.</u> <u>189</u> Business name License No. Address <u>221 W. 4th Hutchinson, Ks</u> Signed <u>Donald J. Darling</u> Date <u>5-19-75</u> Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WW-5