


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

#4 NO

1. Location of well:	County <u>Edwards</u>	Fraction <u>5/16</u> 1/4 1/4	Section number <u>1</u>	Township number T <u>26S</u> S R <u>19W</u> E/W	Range number	
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>75-3 1/2 E. Kinsley</u>			3. Owner of well: <u>Paul Mann</u> R.R. or street: <u>Box 18383</u> City, state, zip code: <u>Wichita, Kansas 67218</u>			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile Sketch map: 			6. Bore hole dia. <u>24</u> in. Completion date <u>6-7-76</u> Well depth <u>79</u> ft.			
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <u>5700</u> Weight: <u>Above or below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>16"</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u> </u> lbs./ft. Dia. <u>16</u> in. to <u>79</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>Y4</u>			
			10. Screen: Manufacturer's name <u>WILL SLT 40</u> Type <u>Johnson</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20</u> Set between <u>39</u> ft. and <u>29</u> ft. <u>39</u> ft. and <u>19</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>40/60 mesh</u>			
			11. Static water level: <u>19</u> ft. below land surface Date <u>6-7-76</u> mo./day/yr.			
12. Pumping level below land surfaces: <u>66</u> ft. after <u>2</u> hrs. pumping <u>250</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>250</u> g.p.m.			13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>			
14. Well head completion: <u> </u> Pitless adapter <u>16"</u> inches above grade			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>14</u> ft.			
16. Nearest source of possible contamination: ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			17. Pump: Manufacturer's name <u> </u> Not installed Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: (Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>EWBANK, INC.</u> 334 Business name <u>901 South Main</u> License No. <u> </u> Address <u>Fairview, Okla.</u> Signed <u>Charles E. Ewbanks</u> Date <u>6-16-76</u> Authorized Representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5