

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction Center of 1/4 NW 1/4	Section number 10	Township number T 26 S R 19 E W	Range number 19
2. Distance and direction from nearest town or city: 7 1/2 S, 1 1/4 W from Kinsley Street address of well location if in city:			3. Owner of well: Kenneth Kuhn R.R. or street: City, state, zip code: Kinsley, KS 67547		
4. Locate with "X" in section below: <div style="text-align: center;"> </div>			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 28 in. Completion date 4-17-77 Well depth 110 ft.
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
					8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
					9. Casing: Material <u>steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 0 ft. depth Wall Thickness: inches or Dia. 16 in. to 50 ft. depth gage No. .188
					10. Screen: Manufacturer's name W. A. Brown Type Bridge Dia. 16 Slot/gauze 10% .188 Length 60 Set between 50 ft. and 110 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 to 5/8
					11. Static water level: 30 ft. below land surface Date 4-17-77 mo./day/yr.
					12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield no test g.p.m.
					13. Water sample submitted: XX No Date 4-17-77 mo./day/yr.
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
		16. Nearest source of possible contamination: ft. 1 mile Direction South Type Farm Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			
		17. Pump: Manufacturer's name Simmons Not installed Model number 4-S-1100 HP 80 Volts 80 Length of drop pipe 100 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)					
18. Elevation: 2221' Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Woofter Drilling, Inc. 343 Business name Hwy 16, Dodge City, KS License No. Address Hwy 16, Dodge City, KS Signed Michael Woofter Date 9/6/77 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5