


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction 1/4 c 1/4 ne 1/4	Section number 11	Township number 26	Range number 19
2. Distance and direction from nearest town or city: 78-5 1/2 W - 1/4 S of Kinsley, Ks. Street address of well location if in city:				3. Owner of well: Midwest Land & Cattle R.R. or street: Box 64 City, state, zip code: Kinsley, Ks. 67547		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 29 in. Completion date _____ Well depth 72 ft. 4-5-75		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Sandy top soil		0		4		9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 16 in. to 72 ft. depth Wall thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 7
Sand and gravel clean coarse loose		4		20		10. Screen: Manufacturer's name _____ Johnson Type steel Dia. 16 Slot/gauge .060 Length 30 Set between 42 ft. and 72 ft. _____ ft. and _____ ft.
Yellow brown clay		20		23		Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8-1/2
Sand & gravel clean coarse loose		23		41		11. Static water level: _____ mo./day/yr. 117 ft. below land surface Date 2-10-75
Brown & white clay		41		51		12. Pumping level below land surfaces: 32 ft. after _____ hrs. pumping 500 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 600 g.p.m.
Yellow brown light gray clay		51		55		13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 2-10-75
Brown sand rock		55		66		14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
Hard sand rock black		66		67		15. Well grouted? <input checked="" type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Sand rock		67		74		16. Nearest source of possible contamination: ft. 2000 Direction sw Type corral Well disinfected upon completion? hth Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Pre clay		76		98		17. Pump: _____ Not installed Manufacturer's name Fairbanks Morse Model number 5-10ma HP _____ Volts _____ Length of drop pipe 60 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Blue shale		98		116		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name Great Bend, Ks. 67530 Address S. Kilgore Signed S. Kilgore Date 6-19-75 Authorized representative
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5