

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Edwards	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 21	Township number T 26 S	Range number R 19 E
2. Distance and direction from nearest town or city: 3 1/2 S 4 W 1/2 S of Charlet, Ks.			3. Owner of well: Tom Fox R.R. or street: none City, state, zip code: Kinsley, Kansas 67547		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 29 in. Completion date 8-23-78 Well depth 108 ft.	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From To		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 108 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7	
				10. Screen: Manufacturer's name Doerrs Type Steel Dia. <input type="checkbox"/> Slot 3/16 Length 40 Set between 108 ft. and 68 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 20-40	
				11. Static water level: 32 ft. below land surface Date 4-6-77	
				12. Pumping level below land surfaces: 41 ft. after 1 hrs. pumping 600 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1400+ g.p.m.	
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 4-6-77	
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 570 Direction SE Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name W.B.R. Model number S-1200 HP 60 Volts <input type="checkbox"/> Length of drop pipe 80 ft. capacity 250 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz-Bemis 134 Business name Great Bend, Ks. 67530 License No. Address 1018 Signed [Signature] Date 10/18/78 Authorized representative	
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5