USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

## WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health ond Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number		
1. Location of well:	Edwards	1/4 1/4 CN	E 1/4		30	т 26 s	r 19	E 🕜	
12 mi. South of Kinsley, KS  Street ordress of well location if in city:					or of well: Lawrence Davison or street: Route 1 state, zip code: Kinsley, KS 67547				
4. Locate with "X" in section below: Sketch map:					code. <u>K</u>	6. Bore hole dia. 24 in. Completion date 2-20-76 Well depth 100 ft.			
NW	bs:					7 Cable tool Rotary Hollow rod Jetted	Bored _X Reve	erse rotary	
E W I I E E - SW SE						8. Use:Domestic Public supply Industry  XXIrrigation Air conditioning Stock  Lawn Oil field water Other			
S S						9. Casing: Material Steel Height: bove below  Threaded Welded Surface in.  RMP PVC Weight 303 lbs./ft.  Dia. 16 in. to60 ft. depth Wall Thickness: inches or			
5. Type and color of	Aile ————————————————————————————————————			From	То	Dia. Loin. to Logo ft. dep			
3. Type did cold of	, marer as					10. Screen: Manufacturer's n			
Sand				0	7	Type Double-slot Slot gauze 1/8	Dia. 16"		
Gray clay				7	22	Set between <u>60</u>	ft. and100	ft.	
Sand & xxx sandy clay				22	29	Gravel pack? Yes Size range of material 3/8-200			
Sand & gravel				29	100	11. Static water level:  _39½ft. below land sur		./day/yr. -76	
				<u> </u>		12. Pumping level below land	I surfaces: N	/C _ g.p.m.	
				<u> </u>		ft. after h	ers. pumping	_ g.p.m. _ g.p.m.	
				<u> </u>		13. Water sample submitted:	mo	./day/ут.	
						14. Well head completion:	Date		
						Pitless adapter	2 Inches above	grade	
						With: X Neat cement		Concrete _	
						16. Nearest source of possible	contamination:	le	
						ft Direction Well disinfected upon comple			
						17. Pump: Manufacturer's name <u>FMC</u>	Not installed Corp./Peer	less 7	
						Model number 12LB-3 Length of drop pipe 70	_ HP <u>80</u> ∨o ft. capacity <u>_</u> 90		
						Type: Submersible	_X Turbin	·   •	
	(Use α second s	heet if needed)				Jet Centrifugal	Recipro	ocating S	
18. Elevation:	19. Remarks:			•	•	20. Water well contractor's of This well was drilled under m		s report	
Topography:						is true to the best of my know	ledge and belief.	=10	
Hill						Clarke Well & F Business name Croat	<del></del>	185 = 1 2	
Slope Upland						Address Signed	Sate Sate	3-18-76 h	
Valley	1					Authorized rep	resentative	-	