

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Edwards	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 2	Township number T 26 S R 20	Range number 20
2. Distance and direction from nearest town or city: 7 1/2 mi 3/4 W 1/8 N of Kinsley, Ks. Street address of well location if in city:				3. Owner of well: Midwest Land & Cattle Co R.R. or street: Box 64 City, state, zip code: Kinsley, Mo. 67547		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 29 in. Completion date 4-14-75 Well depth 40 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sandy top soil		0	2	9. Casing: Material steel Weight: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 40 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7		
Gray clay		2	4 1/2	10. Screen: Manufacturer's name Johnson Type steel Dia. 16 Slot/gage .060 Length 10 Set between 30 ft. and 40 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4-3/8		
Sand and gravel clean coarse loose		4 1/2	40	11. Static water level: 9 ft. below land surface Date 8-22-74		
Brown clay		40	55	12. Pumping level below land surfaces: 32 ft. after 1 hrs. pumping 450 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 450 g.p.m.		
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 8-22-74		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: 1/2 mile Direction ne Type septic tank Well disinfected upon completion? hth Yes <input type="checkbox"/> No <input type="checkbox"/>		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Fairbanks Morse Model number 5-10ma HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe 30 ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Mosencrantz-Bemis 134 Business name Great Bend, Ks. License No. 67530 Address S. Kilgore Signed S. Kilgore Date 6-19-74 Authorized representative		
19. Remarks:						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5