



County <b>Edwards</b>		Fraction <b>SE 1/4</b>		Section number <b>11</b>		Township number <b>T 26 S</b>		Range number <b>R 20</b>		E/W <b>E/W</b>	
1. Location of well: <b>Edwards</b>						3. Owner of well: <b>Paul Mann</b> R.R. or street: <b>Box #18383</b> City, state, zip code: <b>Wichita, Kansas 67218</b>					
2. Distance and direction from nearest town or city: <b>75-1 1/2 E Kinsley</b>						4. Locate with "X" in section below: <div style="display: flex; align-items: center;"><div style="text-align: center;"></div><div style="margin-left: 20px;">Sketch map: </div></div>					
5. Type and color of material						6. Bore hole dia. <b>2 1/2</b> in. Completion date <b>6-7-76</b> Well depth <b>83</b> ft.					
						7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary					
						8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
						9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>74"</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <b>1 1/2</b> in. to <b>83</b> ft. depth. Well Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth. gage No. <b>74</b>					
						10. Screens: Manufacturer's name <b>WA Brown</b> <b>mill slot 32 # 20 Johns</b> Type <b>Wire W</b> Dia. <b>1 1/2</b> Slot/gauze <b>100</b> Length <b>20</b> Set between <b>63</b> ft. and <b>83</b> ft. <b>31</b> ft. and <b>51</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>20/40</b>					
						11. Static water level: <input checked="" type="checkbox"/> mo./day/yr. <b>22</b> ft. below land surface Date <b>6-7-76</b>					
						12. Pumping level below land surfaces: <b>75</b> ft. after <b>2</b> hrs. pumping <b>525</b> g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield <b>525</b> g.p.m.					
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date					
						14. Well head completion: <b>1 1/2" casing</b> Pitless adapter <input type="checkbox"/> Inches above grade					
						15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>15</b> ft.					
						16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No					
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: <b>2255</b> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						19. Remarks: <b>27760</b> <b>26 20 11 NDX</b>					
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>EWBANK, INC.</b> <b>334</b> Business name <b>901 South Main</b> License No. Address <b>Fairview, Okla.</b> Signed <b>Charles Butts</b> Date <b>7-16-76</b> Authorized representative					