

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

OFFERLE
SE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Ford	Fraction NW 1/4 SW 1/4 SE 1/4	Section number 13	Township number T 26 S R 21 E W	Range number 21
----------------------	-----------------------	---	-----------------------------	---	---------------------------

2. Distance and direction from nearest town or city: 15 mi. Southeast of Spearville, KS Street address of well location if in city:	3. Owner of well: Dee Lightcap R.R. or street: City, state, zip code: Offerle, KS 67563
--	---

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 24 in. Completion date 10-10-75
Well depth 30 ft.

7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary

8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other

9. Casing: Material Steel Height: Above or below
Threaded Welded Surface 12 in.
RMP PVC Weight 30.3 lbs./ft.
Dia. 16 in. to 12 ft. depth; Wall Thickness: inches or
Dia. 16 in. to 30 ft. depth; gage No. 7 ga.

5. Type and color of material	From	To
Top soil	0	4
Gravel	4	21
clay	21	30
(Use a second sheet if needed)		

10. Screen: Manufacturer's name W. A. Brown
Type Double-slot Dia. 16"
Slot gauge 1/8 Length 10'
Set between 12 ft. and 22 ft.
ft. and _____ ft.
Gravel pack? Yes Size range of material 3/8-200

11. Static water level: _____ mo./day/yr.
4 ft. below land surface Date 10-10-75

12. Pumping level below land surfaces: N/C
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield _____ g.p.m.

13. Water sample submitted: _____ mo./day/yr.
 Yes No Date _____

14. Well head completion:
 Pitless adapter _____ 12 inches above grade

15. Well grouted? Yes
With: Neat cement Bentonite Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. _____ Direction _____ Type _____
Well disinfected upon completion? Yes No

17. Pump: Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation:
Topography:
 Hill
 Slope
 Upland
 Valley

19. Remarks:
This well is one of five identical wells drilled in the same area for a manifold system hook-up.
TOPO
2255

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Clarke Well & Eq., Inc. 185
Business name License No.
Address Great Bend, KS
Signed [Signature] Date 10-10-75
Authorized representative

26 210 13 NW 1/4 SE