

**WATER WELL RECORD**

**Form WWC-5**

Division of Water Resources; App. No.  

<b>1 LOCATION OF WATER WELL:</b> County: <b>Ford</b>	Fraction $\frac{1}{4}$ $\frac{1}{4}$ <b>SW</b> $\frac{1}{4}$	Section Number <b>19</b>	Township Number T <b>26</b> S	Range Number R <b>21</b> E <b>W</b>
Distance and direction from nearest town or city street address of well if located within city? <p style="text-align: center;"><b>See below</b></p>		<b>Global Positioning Systems</b> (decimal degrees, min. of 4 digits) Latitude: _____ Longitude: _____ Elevation: _____ Datum: _____ Data Collection Method: _____		
<b>2 WATER WELL OWNER:</b> RR#, St. Address, Box # : City, State, ZIP Code :		<b>Rick Heeke</b> <b>301 Sophy St.</b> <b>Spearville, KS 67876</b>		

<b>3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:</b> N <table border="1" style="width: 100%; height: 100%; text-align: center; border-collapse: collapse;"> <tr><td> </td><td> </td><td> </td></tr> <tr><td>-- NW --</td><td> </td><td>-- NE --</td></tr> <tr><td>W</td><td> </td><td>E</td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td><b>X</b> SW --</td><td> </td><td>-- SE --</td></tr> <tr><td> </td><td> </td><td> </td></tr> <tr><td>S</td><td> </td><td> </td></tr> </table>				-- NW --		-- NE --	W		E				<b>X</b> SW --		-- SE --				S			<b>4 DEPTH OF COMPLETED WELL</b> ..... <b>80</b> ..... ft.  Depth(s) Groundwater Encountered (1)..... ft. (2)..... ft. (3)..... ft. WELL'S STATIC WATER LEVEL..... <b>21</b> ..... ft. below land surface measured on mo/day/yr... <b>8-7-06</b> ... Pump test data: Well water was.....ft. after..... hours pumping..... gpm Est. Yield.....gpm: Well water was.....ft. after..... hours pumping..... gpm WELL WATER TO BE USED AS: 5 Public water supply    8 Air conditioning    11 Injection well 1 Domestic    3 Feedlot    6 Oil field water supply    9 Dewatering    12 Other (Specify below) 2 Irrigation    4 Industrial    7 Domestic (lawn & garden)    10 Monitoring well    ..... <b>Stock</b> .....
-- NW --		-- NE --																				
W		E																				
<b>X</b> SW --		-- SE --																				
S																						
Was a chemical/bacteriological sample submitted to Department? Yes ..... No <b>X</b> .....; If yes, mo/day/yr Sample was submitted..... Water well disinfected? Yes <b>X</b> ..... No .....																						

<b>5 TYPE OF CASING USED:</b> 1 Steel    3 RMP (SR) <b>2</b> PVC    4 ABS	5 Wrought Iron    8 Concrete tile 6 Asbestos-Cement    9 Other (specify below) 7 Fiberglass	CASING JOINTS: Glued... <b>X</b> ... Clamped..... Welded..... Threaded.....
Blank casing diameter ..... in. to ..... ft., Diameter ..... in. to ..... ft. Casing height above land surface..... <b>12</b> ..... in., Weight..... <b>2.81</b> ..... lbs./ft. Wall thickness or gauge No. .... <b>.265</b> .....		
TYPE OF SCREEN OR PERFORATION MATERIAL: 1 Steel    3 Stainless Steel    5 Fiberglass <b>7</b> PVC    9 ABS    11 Other (Specify) ..... 2 Brass    4 Galvanized Steel    6 Concrete tile    8 RM (SR)    10 Asbestos-Cement    12 None used (open hole)		
SCREEN OR PERFORATION OPENINGS ARE: 1 Continuous slot    3 Mill slot    5 Guazed wrapped    7 Torch cut    9 Drilled holes    11 None (open hole) 2 Louvered shutter    4 Key punched    6 Wire wrapped <b>8</b> Saw Cut    10 Other (specify) .....		
SCREEN-PERFORATED INTERVALS: From..... <b>40</b> ..... ft. to ..... <b>80</b> ..... ft., From ..... ft. to ..... ft. From..... ft. to ..... ft., From ..... ft. to ..... ft.		
GRAVEL PACK INTERVALS: From..... <b>20</b> ..... ft. to ..... <b>80</b> ..... ft., From ..... ft. to ..... ft. From..... ft. to ..... ft., From ..... ft. to ..... ft.		

<b>6 GROUT MATERIAL:</b>	1 Neat cement <b>2</b> Cement grout <b>3</b> Bentonite    4 Other .....	Grout Intervals: From ..... <b>0</b> ..... ft. to ..... <b>3</b> ..... ft., From ..... <b>3</b> ..... ft. to ..... <b>20</b> ..... ft., From ..... ft. to ..... ft.
What is the nearest source of possible contamination: 1 Septic tank    4 Lateral lines    7 Pit privy    10 Livestock pens    13 Insecticide Storage    16 Other (specify below) 2 Sewer lines    5 Cess pool    8 Sewage lagoon    11 Fuel storage    14 Abandoned water well 3 Watertight sewer lines    6 Seepage pit    9 Feedyard    12 Fertilizer Storage    15 Oil well/gas well .....		
Direction from well? .....		How many feet? ..... <b>N/A</b> .....

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
		<b>See attached log</b>			
		<b>From South Side of Spearville</b>			
		<b>3-1/3rds miles south, 4 miles east,</b>			
		<b>3/4 of a mile south-east side of road</b>			

**7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION:** This water well was **(1)** constructed, **(2)** reconstructed, or **(3)** plugged under my jurisdiction and was completed on (mo/day/year) ..... **8-7-06** ..... and this record is true to the best of my knowledge and belief.  
Kansas Water Well Contractor's License No. .... **208** ..... This Water Well Record was completed on (mo/day/year) ..... **8-28-06** .....  
under the business name of **Minter-Wilson Drilling Co., Inc.** by (signature) *Nora Keller*

**INSTRUCTIONS:** Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Bureau of Water, Geology Section, 1000 SW Jackson St., Suite 420, Topeka, Kansas 66612-1367. Telephone 785-296-5522. Send one to WATER WELL OWNER and retain one for your records. Fee of \$5.00 for each constructed well. Visit us at <http://www.kdhe.state.ks.us/geo/waterwells>.

*The  
Professionals*

# MINTER-WILSON DRILLING CO.

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

INCORPORATED

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

Rick Heeke  
Ford County  
8-7-06

Location: SW $\frac{1}{4}$  19-26-21 - Wright South Side - 12 miles east,  
3/4 of a mile south on the east side of road

Static Water Level - 21 ft.

## Test #1

0' to 2' - Top soil  
2' to 16' - Brown clay - lost circulation at 8 ft.  
16' to 22' - Gray clay  
22' to 49' - Brown clay  
49' to 70' - Fine to medium sand  
70' to 110' - Gray shale - pull down 200