

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

BELLEFONT

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment
Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DDA

1. Location of well: County Ford		Fraction NE se 1/4 se 1/4 se 1/4		Section number 14	Township number T 26	Range number S R 22	E(W)
2. Distance and direction from nearest town or city: 5 s. and 2 E. of Spearville, Ks. Street address of well location if in city:				3. Owner of well: Claude Bachman R.R. or street: R.R. # 2 City, state, zip code: Spearville, Kansas 67976			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8.75 in. Completion date 4-15-76 Well depth 110 ft.			
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material				9. Casing: Material Pite Height: Above or below Threaded <input type="checkbox"/> Welded GI Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight _____ lbs./ft. Dia. 5 in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 0, 250			
				10. Screen: Manufacturer's name Jess and Lowell Type RMP Dia. 5 1/2 in. Slot/gauze 1/16 Length 30 Set between 80 ft. and 110 ft. Gravel pack <input checked="" type="checkbox"/> Size range of materials 1/4" / 1/8"			
				11. Static water level: _____ mo./day/yr. 75 ft. below land surface Date 4-14-76			
				12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping 30 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 25 g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade			
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.			
				16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: _____ Not installed Manufacturer's name Rede Model number 129p071 HP 3/4 Volts 220 Length of drop pipe 84 ft. capacity 30 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hedde Drilling Co. 302 Business name License No. Address R.R.#1 Dodge City, KS 67801 Signed Willie Hedde Jr. Date 5-12-76 Authorized representative			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		CRITICAL WELL BRICK 47' TOPO		2325 47 2278			

26 22 W 14 SESESE 1/4 1/4 1/4