

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

BUCKLIN NW

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

DDD

1. Location of well: County Ford Fraction SE 1/4 SE 1/4 SE 1/4 Section number 36 Township number T 26 S R 22 Range number 22 XW

2. Distance and direction from nearest town or city:  
3 1/2 E. and 6 S. of Spearville, Ks.  
Street address of well location if in city:

3. Owner of well: Wayne Daubert  
R.R. or street: Spearville, Kansas 67876  
City, state, zip code:

4. Locate with "X" in section below: Sketch map:

1 Mile

6. Bore hole dia. 12 in. Completion date \_\_\_\_\_  
Well depth 74 ft. 8-04-76

7.  Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material PVC Height: Above or below \_\_\_\_\_  
Threaded \_\_\_\_\_ Welded  Surface 12 in.  
RMP \_\_\_\_\_ PVC \_\_\_\_\_ Weight \_\_\_\_\_ lbs./ft.  
Dia. 5 in. to 74 ft. depth Wall Thickness: \_\_\_\_\_ inches or  
Dia. \_\_\_\_\_ in. to \_\_\_\_\_ ft. depth gauge No. 265

5. Type and color of material	From	To
Top soil <u>ldk blf</u>	<u>0</u>	<u>5</u>
Clay <u>vd</u>	<u>6</u>	<u>15</u>
Fine sand <u>well</u>	<u>16</u>	<u>45</u>
Med. sand <u>well</u>	<u>46</u>	<u>55</u>
Yellow clay <u>vd</u>	<u>56</u>	<u>63</u>
Black shale	<u>64</u>	<u>74</u>
<u>Block 56'</u>		
<u>31</u>		
<u>25' sat thick</u>		
<u>in of</u>		

10. Screen: Manufacturer's name Jess & Lowell  
Type PVC Dia. 5"  
Slot/gauze 1/8" Length 20'  
Set between 54 ft. and 74 ft.  
ft. and \_\_\_\_\_ ft.  
Gravel pack?  Yes Size range of material 3/16"

11. Static water level: \_\_\_\_\_ mo./day/yr.  
31 ft. below land surface Date 6/22/76

12. Pumping level below land surfaces:  
\_\_\_\_\_ ft. after \_\_\_\_\_ hrs. pumping \_\_\_\_\_ g.p.m.  
\_\_\_\_\_ ft. after \_\_\_\_\_ hrs. pumping \_\_\_\_\_ g.p.m.  
Estimated maximum yield \_\_\_\_\_ g.p.m.

13. Water sample submitted: \_\_\_\_\_ mo./day/yr.  
 Yes  No Date \_\_\_\_\_

14. Well head completion: Pitless Unit  
 Pitless adapter \_\_\_\_\_ Inches above grade

15. Well grouted?  yes  
With:  Neat cement  Bentonite  Concrete  
Depth: From 4 ft. to 14 ft.

16. Nearest source of possible contamination:  
ft. 300 Direction NE Type well in use  
Well disinfected upon completion?  Yes  No

17. Pump: \_\_\_\_\_ Not installed  
Manufacturer's name Aermotor  
Model number SD12 HP 3/4 Volts 220  
Length of drop pipe 60 ft. capacity 10 g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

18. Elevation: \_\_\_\_\_

19. Remarks:  
23 54  
56  
2298  
TOPO

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
Friesen Windmill 252  
Business name License No.  
Address Meade, Kansas 67864  
Signed John Friesen Date 8-6-76  
Authorized representative

26  
23  
36  
SESESE  
1/4 1/4 1/4