


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

STEARVILLE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction NE 1/4 SE 1/4 SW 1/4	Section number 20	Township number T 26 S R 23 E/W	Range number
2. Distance and direction from nearest town or city: 1 1/2 mi. East 3/8 mi. South of Wright Ks. Street address of well location if in city:				3. Owner of well: Stanley Kliesen R.R. or street: Wright, Kansas 67882 City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile Sketch map:				6. Bore hole dia. 26 in. Completion date: 9/11/76 Well depth 416 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				From	To	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.86 lbs./ft. Dia. 16 in. to 16 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219
Clay				0	220	10. Screen: Manufacturer's name Lakewood Type Millalot Dia. 16" Slot/gauze 1/8x2 Length 180 Set between 236 ft. and 416 ft. Gravel pack? Yes Size range of material 1/4 - 1/2
Sandstone (good)				220	400	11. Static water level: 62 ft. below land surface Date 1/19/76
One hard spot at 397 and another at 398						12. Pumping level below land surfaces: 4 00 ft. after 6 days hrs. pumping 1100 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1100 g.p.m.
						13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date
TRICK ?						14. Well head completion: Pitless adapter 12 inches above grade
						15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: NA ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: Not installed Manufacturer's name Worthington Model number 7S-12H-110 Volts Length of drop pipe 200 ft. capacity 1100 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
18. Elevation:		19. Remarks:		21. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland Level <input type="checkbox"/> Valley		2502 1070		High Plains Drilling & Supply 136A Business name License No. Address 102 N 3rd Garden City Ks Signed B. D. Thabness Date 9-16-76 Authorized representative		