USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

WRIGHT

Kansas Department of Health and **Environment-Division of Environment** (Water well Contractors)

DDA Topeka, Kansas 66620 County Fraction Section number Township number Range number NE _{1/4} 1. Location of well: Ford SE_{1/4}SE 13 26 24 2. Distance and direction from nearest town or city: 3. Owner of well: Wright, City of East edge of Wright, KS R.R. or street: c/o City Clerk Street address of well location if in city: City, state, zip code: Wright, KS 67882 6. Bore hole dia. 17 in. Completion date 10-8-17

Well depth 259 ft. 4. Locate with "X" in section below: Sketch map: 7. __ Cable tool __ Rotary __ Driven __ Dug __ Hollow rod __ Jetted __ Bored X Reverse rotary - NW --8. Use: __ Domestic __ Public supply __ Industry __ Irrigation __ Air conditioning __ Stock __ Lawn __ Oil field water X Other 9. Casing: Material stee Height: Above r below Threaded Welded X Surface 36 in. RMP PVC Weight 27 lbs./ft. Dia. 8 in. to 3 ft. depth Wall Thickness: inches or Dia. 8 in. to 227 ft. depth gage No. 300Above grade -- 1 Mile -5. Type and color of material From 10. Screen: Manufacturer's name ___ Doerr Top Soil Stainless #304_{Dia..} Slot gauze 1/16" 321 Brown Clay __ft. and ___ Brown & White Clay 9 55 Gravel pack? yes Size range of material 3/8-200 Brown & White Clay, with hard lime streaks 55 74 11. Static water level: ____ft. below land surface Date Brown & Gray Clay 1 74 12. Pumping level below land surfaces Not Checked ____ ft. after _____ hrs. pumping _____ g.p.m. ___ hrs. pumping __ 87 104 Estimated maximum yield ____ Red & Gray Dakota Clay 193 13. Water sample submitted: Sandstone & Clay Streaks 193 201 14. Well head completion: Pitless adapter <u>36</u> Inches above grade Sandstone 201 250 15. Well grouted? <u>yes</u> With: X Neat_cement ___ Sandstone with clay streaks 250 256 __ Bentonite ___ Depth: From 0 ft. to 60 ft. 16. Nearest source of possible contamination: ft. ______ Direction _____ Type __FIELD Well disinfected upon completion? ___ X__ Yes _ 17. Pump: Not installed Manufacturer's name Berkeley Pump Co. Model number 652AL-7 HP 20 Volts 230Length of drop pipe 241.5 ft. capacity 150 g.p.m. Type:
X
Submersible Turbine __ Reciprocating (Use a second sheet if needed) _ Centrifugal Other 18. Elevation: 19. Remarks: 20. Water well contractor's certification: Well to be used for maintaining water This well was drilled under my jurisdiction and this report level in new lagoons - Sewage disposal systems true to the best of my knowledge and belief. Topography: Well completed in accordance with all spec-Clarke Well & Equip., Inc 185 Hill ification for future use as public supply well.

Upland