

1 LOCATION OF WATER WELL
 County: **Ford** Fraction $\frac{1}{4}$ $\frac{1}{4}$ **SW** $\frac{1}{4}$ Section Number **19** Township Number **T 26 S** Range Number **R 24 E W**

Distance and direction from nearest town or city? **From Country Club on N. Avenue C 1 East - $\frac{1}{2}$ North** Street address of well if located within city?

2 WATER WELL OWNER: **Dodge City Country Club**
 RR#, St. Address, Box #: **North Avenue C** Board of Agriculture, Division of Water Resources
 City, State, ZIP Code: **Dodge City, 67801** Application Number:


3 DEPTH OF COMPLETED WELL: **230** ft. Bore Hole Diameter: **30** in. to **230** ft., and in. to ft.
 Well Water to be used as:
 1 Domestic 3 Feedlot 5 Public water supply 8 Air conditioning 11 Injection well
 2 Irrigation 4 Industrial 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
 7 Lawn and garden only 10 Observation well
 Well's static water level: **126** ft. below land surface measured on **December** month **7** day **1979** year
 Pump Test Data: Well water was **165** ft. after **2** hours pumping **1250** gpm
 Est. Yield **1400** gpm: Well water was **185** ft. after **3** hours pumping **1400** gpm

4 TYPE OF BLANK CASING USED:
 1 Steel 3 RMP (SR) 5 Wrought iron 8 Concrete tile Casing Joints: Glued Clamped
 2 PVC 4 ABS 6 Asbestos-Cement 9 Other (specify below) Welded
 7 Fiberglass Threaded
 Blank casing dia: **16** in. to **230** ft., Dia in. to ft., Dia in. to ft.
 Casing height above land surface: **12** in., weight **36.4** lbs./ft. Wall thickness or gauge No. **.219**

TYPE OF SCREEN OR PERFORATION MATERIAL:
 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)
 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)
 Screen or Perforation Openings Are:
 1 Continuous slot 3 Mill slot 5 Gauzed wrapped 8 Saw cut 11 None (open hole)
 2 Louvered shutter 4 Key punched 6 Wire wrapped 9 Drilled holes
 7 Torch cut 10 Other (specify)
 Screen-Perforation Dia: **16** in. to **230** ft., Dia in. to ft., Dia in. to ft.
 Screen-Perforated Intervals: ~~From~~ Perf **180** ft. to **197** ft., ~~From~~ Screen **197** ft. to **227** ft.
~~From~~ Perf **227** ft. to **230** ft., From ft. to ft.
 Gravel Pack Intervals: From **20** ft. to **230** ft., From ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other
 Grouted Intervals: From **0** ft. to **20** ft., From ft. to ft., From ft. to ft.
 What is the nearest source of possible contamination:
 1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well
 2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)
 3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines **Center of $\frac{1}{2}$ Section N/A**
 Direction from well How many feet ? Water Well Disinfected? Yes No
 Was a chemical/bacteriological sample submitted to Department? Yes No If yes, date sample was submitted month day year Pump Installed? Yes No
 If Yes: Pump Manufacturer's name **Used customers pump** Model No. HP Volts
 Depth of Pump Intake **200** ft. Pumps Capacity rated at gal./min.
 Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on **December** month **21** day **1979** year
 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. **208**
 This Water Well Record was completed on **December** month **11** day **1980** year under the business name of **Minter Wilson Drilling Co., Inc.** by (signature) *M. Irene De Keyser Oghy*

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

 FROM TO LITHOLOGIC LOG FROM TO LITHOLOGIC LOG
 Test log attached

ELEVATION:
 Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY
T
R
E
SEC.
1/4
C
5
1/4

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DODGE CITY COUNTRY CLUB
FORD COUNTY
12-15-76

Location: SW 19-26-24 Dodge City north by pass Village
Square 1 mile east, 1 mile south 2/10 of
mile west, 50 Ft. north in field.

Static Water Level- 118'

Test #1

0	6	Top soil
6	44	Brown sandy clay
44	59	Brown white sandy clay hard
59	65	White clay gravel mixed hard
65	69	Fine to med. sand and gravel
69	78	Light brown sand clay
78	103	Fine to med. sand and gravel
103	116	Brown sandy clay
116	143	Brown sandy clay traces of gravel and rock
143	157	Brown sandy clay traces of cemented sand stones
157	166	Fine sand
166	176	Brown sandy clay
176	185	Fine to med. sand and gravel 15% clay
185	192	Brown sandy clay 10% gravel streak
192	200	Med. sand to med. coarse gravel yellow white rock
200	227	Med. coarse gravel mixed yellow white rock Loose
227	254	Brown sandy clay
254	258	Yellow clay
258	260	Shale

X