

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

WRIGHT

1. Location of well:		County Ford	Fraction NE 1/4 NW 1/4 SW 1/4	Section number 25	Township number T 26	Range number S R 27	E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			5 mil east Highway 50				
3. Owner of well:			Tri State Industries				
R.R. or street:			P O Box 1422				
City, state, zip code:			Dodge City, Ks 67801				
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>10"</u> in. Completion date <u>Aug 15, 1979</u> Well depth <u>230</u> ft.		
		<p>Septic tank ↓ Building ↓ Jess' X WELL</p>			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		9. Casing: Material <u>Plastic</u> Height: Above or below <u>***</u> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>18"</u> in. RMP <input type="checkbox"/> PVC <u>Glue</u> Weight <u>250</u> lbs./ft. Dia. <u>6</u> in. to <u>100</u> ft. depth Wall Thickness: inches or Dia. <u>6</u> in. to <u>120</u> ft. depth gage No. <u>250</u>			10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>Plastic</u> Dia. <u>6"</u> Slot/gauze <u>1/4</u> Length <u>60'</u> Set between <u>100</u> ft. and <u>120</u> ft. <u>190</u> ft. and <u>230</u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4</u>		
		11. Static water level: _____ mo./day/yr. <u>73'</u> ft. below land surface Date <u>9-10-79</u>			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>40</u> g.p.m.		
		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter Unit <u>1 1/2</u> inches above grade		
		15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>20</u> ft.			16. Nearest source of possible contamination: ft. <u>200</u> Direction <u>NW</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
		17. Pump: _____ Not installed Manufacturer's name <u>Sta Rite</u> Model number <u>8P4Bo2S</u> HP <u>5</u> Volts <u>220</u> Length of drop pipe <u>210</u> ft. capacity <u>40</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Cragg Well Drilling 111</u> Business name License No. Address <u>Dodge City, Ks 67801</u> Signed <u>Mark Cragg</u> Date <u>10-3-79</u> Authorized representative		
18. Elevation: <u>Level</u> Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: <u>10PO</u> <u>2521</u> <u>120</u> <u>2401</u>					

T
R
S
1/4
1/4
1/4
NE NW SW