

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

WRIGHT

75 75 12

1. Location of well: County FORD		Fraction NW 1/4 NW 1/4 NW 1/4		Section number 30		Township number T 26 S		Range number R 24 E/W	
2. Distance and direction from nearest town or city: Access Street west of Dodge				3. Owner of well: Sue Bove R.R. or street: HAGGARD POON City, state, zip code: Dodge City KS					
4. Locate with "X" in section below:				Sketch map:				6. Bore hole dia. 8 in. Completion date 6/6/76 Well depth 240 ft.	
								7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material				From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Topsoil				0		3		9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 17 in. RMP <input type="checkbox"/> PVC Blue Weight 250 lbs./ft. Dia. 5 in. to 240 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250	
Chry				3		31		10. Screen: Manufacturer's name Jess & Vowen Type PVC Dia. 5 Slot/gauze 1/16 Length 3 Set between 240 ft. and 210 ft. ft. and <input type="checkbox"/> ft.	
Rock & Cray				31		96		Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8	
Gravel & Cray				96		113		11. Static water level: 136 ft. below land surface Date 6/6/76 <small>mo./day/yr.</small>	
Rock				113		144		12. Pumping level below land surfaces: N/A <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
Rock Cray & SAND				144		210		13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
GRAVEL				210		238		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 17 inches above grade	
Rock & Cray				238		-		15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.	
								16. Nearest source of possible contamination: ft. 75 Direction EAST Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
								17. Pump: <input type="checkbox"/> Not installed Manufacturer's name RODA Model number 170 10SP HP 1 1/2 Volts 220 Length of drop pipe 168 ft. capacity 21 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
								20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CRAGE DRILLING 111 Business name License No. Address RT 1 Signed Roy Olney Date 6/6/76 Authorized representative	
18. Elevation:		19. Remarks: Check with local State Health ON DISTANCE FROM SEPTIC TANK WAS GIVEN OKAY 101' 2599 238 2361'							
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley									

26 24 W E 30 1/4 1/4 1/4 Sec