

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

77 Dodge

K137

1. Location of well: County Ford		Fraction NE 1/4 NW 1/4 NW 1/4	Section number 32	Township number T 24 S R 24 E	Range number 24 E
2. Distance and direction from nearest town or city: East of Dodge City 1/2 mile on the FORT DODGE RD.			3. Owner of well: Merv Cook R.R. or street: Dodge City, KS City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 1 1/4 in. Completion date 11-7-77 Well depth 145 ft.	
		<p>Dodge City → 1/2 mile East</p>		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Top Soil & Clay			0	9. Casing: Material PIST Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight SCH 40 lbs./ft. Dia. 1 in. to 1 1/4 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 40	
Sand + Gravel, Some Clay			15	10. Screen: Manufacturer's name Homemade Type <input type="checkbox"/> Dia. <input type="checkbox"/> Slot/gauze Saw blade length <input type="checkbox"/> Set between 105 ft. and 145 ft. ft. and <input type="checkbox"/> ft.	
Sand & good Gravel			40	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 to 3/8	
				11. Static water level: <input type="checkbox"/> mo./day/yr. 40 ft. below land surface Date 11-7-77	
				12. Pumping level below land surfaces: 40 ft. after 1 hrs. pumping 7 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.	
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>	
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: none ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Grundfos Model number <input type="checkbox"/> HP 1/2 Volts 230 Length of drop pipe 100 ft. capacity 145 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Brown Lumber Co Inc 217 Business name Becklin License No. <input type="checkbox"/> Address Albert in beam Date 11-7-77 Signed Albert in beam Authorized representative	

26 24 W 32 NE 1/4 NW 1/4
 Sec 1/4 1/4 1/4

145
2290