


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

CCC TH Dodge

1 Location of well:	County FORD	Township name GRAND View	Fraction SW 1/4 SB 1/4 SW 1/4	Section number 33	Town number 26	Range number 24
Distance and direction from nearest town or city: 1m EAST Dodge				3 Owner of well: HELEN RUBY		
Street address of well location if in city:				Address: Ft Dodge Rd, Dodge City ks		
Locate with "X" in section below: N  W E S 1 Mile		Sketch map:		4 Well depth: 150 ft. Date of completion 9/26/18 Well diameter 8 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Soil				7 Casing: Material ARC Height: above /below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 20 in. Diam. 6 1/2 Weight 125 lbs./ft. 5 in. to 150 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				8 Screen: Manufacturer Jess + Lowell Type PVC Dia. 5 Top gauze 1/16 Length 3 Set between 120 ft. and 150 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/8		
SAND				9 Static water level: 31 ft. below land surface Date 9/26/18		
GRAVEL				10 Pumping level below land surfaces: N/A ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
CLAY				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
GRAVEL				12 Well head completion: <input checked="" type="checkbox"/> Pitless adapter 20 inches above grade		
Grouted between GRAVELS				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 3 ft. to 13 ft.		
				14 Nearest source of possible contamination: ft. 100 Direction W Type Seasonal Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
(use a second sheet if needed)				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Reda Model number 100102 HP 1 hp volts 220 Length of drop pipe 84 ft. capacity 1000 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope level <input type="checkbox"/> Upland <input type="checkbox"/> Valley TOPO		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Craig Well Drilling 111 Business Name License No. Address Ft Dodge City KS Signed Craig Drury Date 9/27/18 Authorized representative		