

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: Fraction Section Number Township Number Range Number
 COUNTY: FORD SW 1/4 SW 1/4 NW 1/4 18 T 26 S R 24 W

Distance and direction from nearest town or city street address of well if located within city?
 114 ROAD ON HIGHWAY 50 BYPASS - 3/4 NORTH

2 WATER WELL OWNER: NIGHTENGALE, JIM
 RR#, St. Address, Box #: NORTH STAR ROUTE 10816 115th RA Board of Agriculture, Division of Water Resources
 City, State, ZIP code: DODGE CITY, KS 67801- Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 4 DEPTH OF COMPLETED WELL 205 ELEVATION: 0
 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.
 WELL'S STATIC WATER LEVEL 82 ft. below land surface measured on mo/day/yr 10/10/07
 Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm
 Estimated Yield 45 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm
 Bore Hole Diameter 10 in. to 205 ft., and in. to 0 ft.
 WELL WATER TO BE USED AS: DOMESTIC
 Was a chemical/bacteriological sample submitted to department? No ;
 If yes, mo/day/yr sample was submitted Water well disinfected? Yes

5 TYPE OF BLANK CASING USED: CERTA LOC CASIN CASING JOINTS: CERTA-LOC
 Blank casing diameter 5 in. to 205 ft., Dia in. to 0 ft., Dia in. to 0 ft.
 Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21
 TYPE OF SCREEN OR PERFORATION MATERIAL: PVC
 SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 160 ft. to 200 ft., From 0 ft. to 0 ft.
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.
 GRAVEL PACK INTERVALS: From 25 ft. to 205 ft., From 0 ft. to 0 ft.
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE
 Grout Intervals: From 5 ft. to 25 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.
 What is the nearest source of possible contamination: NONE
 Direction from well? How many feet? 0

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	20	01 TOPSOIL 05 CLAY 35 CALACHIE			
20	40	35 CALACHIE WHITE 05 CLAY			
40	60	29 SANDSTONE 10 FINE-MEDSAND 19 LAYERS			
60	80	02 FINE SAND 05 CLAY 19 LAYERS			
80	100	02 FINE SAND 17 CLAY LAYERS 35 CALACHIE			
100	120	35 CALACHIE 02 FINE SAND			
120	160	02 FINE SAND 17 CLAY LAYERS			
160	190	37 FIN-COAR SAN 06 SMALL GRAVEL			
190	200	32 TAN CLAY			
200	220	32 TAN CLAY 16 GRAY CLAY 07 BLUE SHALE			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 10/11/07 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 11/01/07 under the business name of JOE'S WELL SERVICE, INC. by (signature) *Judith Cook*