WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: COUNTY: FORD	Fraction NW 1/4 NW 1/4 NE 1/4	Section Number 22	Township Number T 26 S	Range Number R 24 E

Distance and direction from nearest town or city street address of well if located within city?
FROM DODGE CITY, KS. - 4 EAST ON HIGHWAY 50

2 WATER WELL OWNER: FARMLAND INDUSTRIAL INC.
RR#, St. Address, Box # : P.O. BOX 1337
City, State, ZIP code : DODGE CITY, KS 67801-

Board of Agriculture, Division of Water Resources
Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:



4 DEPTH OF COMPLETED WELL 140 ELEVATION: 0
Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.

WELL'S STATIC WATER LEVEL 91 ft. below land surface measured on mo/day/yr 10/31/94
Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm

Estimated Yield 15 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm

Bore Hole Diameter 10 in. to 140 ft., and in. to 0 ft.

WELL WATER TO BE USED AS: INDUSTRY

Was a chemical/bacteriological sample submitted to department? No ;
If yes, mo/day/yr sample was submitted Water well disinfected? Yes

5 TYPE OF BLANK CASING USED: PVC CASING JOINTS: GLUED
Blank casing diameter 5 in. to 140 ft., Dia in. to 0 ft., Dia in. to 0 ft.
Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21
TYPE OF SCREEN OR PERFORATION MATERIAL: PVC
SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 95 ft. to 140 ft., From 0 ft. to 0 ft.
From 0 ft. to 0 ft., From 0 ft. to 0 ft.
GRAVEL PACK INTERVALS: From 80 ft. to 140 ft., From 0 ft. to 0 ft.
From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE
Grout Intervals: From 4 ft. to 25 ft., From 25 ft. to 80 ft., From 0 ft. to 0 ft.
What is the nearest source of possible contamination: ABANDONED WELL
Direction from well? NORTHEAST How many feet? 15

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	7	TOPSOIL CLAY			
7	22	SANDY CLAY			
22	43	BROWN CLAY			
43	60	CALACHIE GRAY			
60	81	BROWN CLAY SAND ROCK			
81	120	SANDY CLAY			
120	130	FINE SAND CLAY			
130	138	YELLOW CLAY SAND			
138	160	YELLOW CLAY			
160	200	SHALE SANDSTONE			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 11/14/94 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 12/20/94 under the business name of JOE'S WELL SERVICE, INC. by (signature) Jerrit Crist