

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DODGE CITY

1. Location of well: County FORD		Fraction SW 1/4 SW 1/4 NE 1/4		Section number 4	Township number T 26	Range number S R 25 E/W
2. Distance and direction from nearest town or city: 3 miles N Dodge				3. Owner of well: LEN CRUM		
Street address of well location if in city:				R.R. or street: 803 3RD		
				City, state, zip code: Dodge City KS		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 4/6/76		
				Well depth 90 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 1 1/2 in. RMP PVC Weight 250 lbs./ft. Dia. 5 in. to 90 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
5. Type and color of material		From		To		
Topsoil		0		1		
Clay		1		16		
Rock		16		51		
SAND & Rock		51		61		
GRAVEL		61		76		
GRAVEL, CLAY & Rock		76		89		
Rock		89		—		
				10. Screen: Manufacturer's name Fast Flow		
				Type PVC Dia. 5		
				Slot/gauge 11/16 Length 3		
				Set between 70 ft. and 90 ft. ft. and ft.		
				Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8		
				11. Static water level: _____ no./day/yr. 61 ft. below land surface Date 4/6/76		
				12. Pumping level below land surfaces: N/A _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
				13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: _____ Pitless adapter 16 Inches above grade		
				15. Well grouted? _____ With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. 110 Direction CORRAL Type EAST Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		2567 85 1482				
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. CRAGG DRILLING License No. 111 Business name _____ Address RT 1 Signed Ray Cragg Date 4/6/76 Authorized representative				

T 26
 R 25
 E/W
 Sec 4
 1/4 1/4 1/4