

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

AAC

1. Location of well: County **Ford** Fraction **SW 1/4 NE 1/4 NE 1/4** Section number **4** Township number **T 26 S R 25 E/W**

2. Distance and direction from nearest town or city: **2 mi north-1 west-.6 north-.4 west**  
Street address of well location if in city:

3. Owner of well: **Jay Raber**  
R.R. or street: **Rt. 2**  
City, state, zip code: **Dodge City, Kansas**

4. Locate with "X" in section below: Sketch map:  
N  
W  
S  
E  
1 Mile  
1219' west of center of road  
1350' north of 1/2 mi line  
section is a correction section - not standard in size

5. Type and color of material

	From	To
Surface	0	3
Brown, gray and coleche clay	3	40
Fine to half med. sand with 10% clay	40	48
Hard rock	48	49
Good loose med. sand and gravel	49	74
Fine sand and sandrock with 40% clay	74	88
Yellow clay	88	102
Blue shale	102	105

6. Bore hole dia. **28** in. Completion date **8-11-77**  
Well depth **90** ft.

7. Cable tool  Rotary  Driven  Dug  
 Hollow rod  Jetted  Bored  Reverse rotary

8. Use:  Domestic  Public supply  Industry  
 Irrigation  Air conditioning  Stock  
 Lawn  Oil field water  Other

9. Casing: Material **metal** Height: Above or below  
Threaded  Welded  Surface **10** in.  
RMP  PVC  Weight **31.66** lbs./ft.  
Dia. **16** in. to **90** ft. depth Wall Thickness: inches or  
Dia.  in. to  ft. depth gage No. **188**

10. Screens: Manufacturer's name **W.A. Brown**  
Type **17% Free-flo** Dia. **16**  
Slot/gauze **1/8** Length **50**  
Set between **40** ft. and **90** ft.  
ft. and  ft.  
Gravel pack? **yes** size range of material **1/2 down**

11. Static water level:  mo./day/yr.  
**45** ft. below land surface Date **8-11-77**

12. Pumping level below land surfaces:  
**85** ft. after **3** hrs. pumping **450** g.p.m.  
ft. after  hrs. pumping  g.p.m.  
Estimated maximum yield **450** g.p.m.

13. Water sample submitted:  mo./day/yr.  
Yes  No Date

14. Well head completion:  
 Pitless adapter  Inches above grade

15. Well grouted? **no**  
Wth:  Neat cement  Bentonite  Concrete  
Depth: From  ft. to  ft.

16. Nearest source of possible contamination:  
ft. **1000** Direction **south** Type **farm**  
Well disinfected upon completion?  Yes  No

17. Pump:  Not installed  
Manufacturer's name **Goulds**  
Model number **10J10** HP **40** Volts   
Length of drop pipe **80** ft. capacity **375** g.p.m.  
Type:  
 Submersible  Turbine  
 Jet  Reciprocating  
 Centrifugal  Other

18. Elevation: Topography:  Hill  Slope  Upland  Valley

19. Remarks: **10' of grout and pump slab to be furnished by the customer-he knows this is a regulation**  
**Jay Pal Raber** 2554  
10170 88  
2466

20. Water well contractor's certification:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.  
**Ace-Hi International** 190  
Business name **Dodge City, Kansas** License No.  
Address **Dodge City, Kansas**  
Signed **Carl Cottrell** Date **7-6-77**  
Authorized representative

842  
255  
4  
STUNE NE  
1/4 1/4 1/4