

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Ford	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 9	Township number T 26 S R 25 E/W	Range number
2. Distance and direction from nearest town or city: 2 miles SW of DC Street address of well location if in city: Highway 56, 1/4 So.			3. Owner of well: Jon Bailes R.R. or street: 2704 Westview City, state, zip code: Dodge City, Ks 67801			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: X well House Septic		6. Bore hole dia. 8 in. Completion date 5-9-78 Well depth 143 ft.		
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Topsoil		0	2	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sand		2	35	9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC Glue Weight 250 lbs./ft. Dia. 5 in. to 5 ft. depth Wall Thickness: inches or Dia. 5 in. to 5 ft. depth gage No. 250		
GRAVEL		35	140	10. Screen: Manufacturer's name Jess & Lowell Type Plastic Dia. 5 in. Slot size 1/16 Length 30 in. Set between 110 ft. and 140 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 1/4 in.		
Clay		140	—	11. Static water level: _____ mo./day/yr. 75 ft. below land surface Date 5/4/78		
ROCK 140				12. Pumping level below land surfaces: N/A _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
75				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
65 cut fluid				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 16 inches above grade		
HID 617				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 20 ft.		
Dy				16. Nearest source of possible contamination: ft. 100 Direction S Type Septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
2585				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cragg Well Drilling 111 Business name License No. Address 1308 So Second Dodge City Signed Larry Phay Date 5/4/78 Authorized representative		

CORRECTION(S) TO WATER WELL RECORD (WWC-5)

(to rectify lacking or incorrect information)

County: Ford

Location listed as:

Section-Township-Range: 9-T26S-R2SW

Fraction ($\frac{1}{4}$ $\frac{1}{4}$ $\frac{1}{4}$): _____

Location changed to:

9-T27S-R2SW

Other changes: Initial statements: _____

Changed to: _____

Comments: Based on directions, houses in area, current addresses, and
so on, this well was moved.

verification method: _____

initials: DAH date: Oct. 17, 2007