

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

D.C.C.

1. Location of well:		County Ford	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 13	Township number T 26 S R 25 E/W	Range number
2. Distance and direction from nearest town or city: Highway 50 Bypass			3. Owner of well: Fun Center Bowling Alley			
Street address of well location if in city:			R.R. or street: Highway 50 Bypass			
			City, state, zip code: Dodge City, Ks 67801			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>8</u> in. Completion date _____		
				Well depth <u>230</u> . <u>12-22-77</u>		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input checked="" type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <u>Plastic</u> Weight: Above or below Threaded _____ Welded _____ Surface <u>18</u> in. RMP _____ PVC <u>Glue</u> Weight <u>280</u> lbs./ft. Dia. <u>5</u> in. to <u>230</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>		
5. Type and color of material		From	To	10. Screen: Manufacturer's name <u>Jess & Lowell</u>		
<u>Topsoil</u>		<u>0</u>	<u>3</u>	Type <u>Plastic</u> Dia. <u>5</u> " Slot/gauge _____ Length <u>30</u> "		
<u>Clay</u>		<u>3</u>	<u>100</u>	Set between <u>200</u> ft. and <u>230</u> ft. _____ ft. and _____ ft.		
<u>Rock</u>		<u>100</u>	<u>104</u>	Gravel pack? <u>yes</u> Size range of material <u>1/4</u> "		
<u>SAND</u>		<u>104</u>	<u>126</u>	11. Static water level: _____ mo./day/yr. <u>105</u> ft. below land surface Date <u>4/20/77</u>		
<u>Clay</u>		<u>126</u>	<u>200</u>	12. Pumping level below land surfaces: <u>N/A</u> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
<u>GRAVEL</u>		<u>200</u>	<u>230</u>	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless <u>18</u> " _____ inches above grade		
				15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>20</u> ft.		
				16. Nearest source of possible contamination: ft. <u>100</u> Direction <u>South</u> Type <u>Septic tank</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>Pumpster</u> Model number <u>DH100SA</u> HP <u>1</u> Volts <u>230</u> Length of drop pipe <u>184</u> ft. capacity <u>10</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine <input type="checkbox"/> Jet _____ Reciprocating <input type="checkbox"/> Centrifugal _____ Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Geagg Well Drilling 111</u> Business name License No. _____ Address <u>1308 So Second Dodge City</u> Signed <u>Ray Olson</u> Date <u>4/20/77</u> Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>2578</u> <u>230</u> <u>2348</u>				

26
 R 25 W
 Sec 13
 SW 1/4 SE
 1/4 1/4 1/4