USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

DODGE CITY

DAE

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County	Township name	Fraction	Section number	Town number	Range number
	FORD	Dodge	NW 1/4 NE 1/4 SE 1/4	13	26	25

Distance and direction from nearest town or city: 2m N Dodge

Street address of well location if in city:

3 Owner of well: DONALD KIESEN

Address: Rt 2, Dodge City Ks

Locate with "X" in section below: Sketch map:

N, W, E, S, X, 1 Mile

4 Well depth: 200 ft. Date of completion Sept 1975
Well diameter 8 in.

5 ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary

6 Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Commercial ☐ Test well ☐ _____

7 Casing: Material PVC Height: (above) below
Threaded ☐ Welded ☐ Surface 20 in.
Diam. Glue Weight 25 lbs./ft. WALL
5 in. to 200 ft. depth Drive shoe? ☐ Yes ☒ No
___ in. to ___ ft. depth

2

Type and color of material	From	To
Soil	0	3
Clay	3	64
Gravel & Clay	64	70
Clay	70	164
Gravel	164	200
BROCK 200'		
84		
116' set back		
(use a second sheet if needed)		

8 Screen:
Manufacturer Jess & Lowell
Type PVC Dia. 5
(Slot) gauze 11/6 Length 3
Set between 170 ft. and 200 ft.
Fittings:
Gravel pack ☒ Yes ☐ No Size range of material 116

9 Static water level:
84 ft. below land surface Date 10 sep 75

10 Pumping level below land surfaces: N/A
___ ft. after ___ hrs. pumping ___ g.p.m.
___ ft. after ___ hrs. pumping ___ g.p.m.
Estimated maximum yield ___ g.p.m.

11 Water sample submitted:
☐ Yes ☒ No Date ___

12 Well head completion:
☒ Pitless adapter ☐ Inches above grade

13 Well grouted? ☒ Yes ☐ No
☒ Neat cement ☐ Bentonite ☐ _____
Depth: From 3 ft. to 13 ft.

14 Nearest source of possible contamination:
ft. 100 Direction W Type Seepage
Well disinfected upon completion? ☒ Yes ☐ No

15 Pump: ☐ Not installed
Manufacturer's name Reda
Model number 100 18P10 HP 1 Volts 230
Length of drop pipe 168 ft. capacity 1000 g.p.m. per hr
Type:
☒ Submersible ☐ Turbine
☐ Jet ☐ Reciprocating
☐ Certrifugal ☐ Other

16 Remarks: elevation

Topography:
☐ Hill
☒ Slope
☐ Upland
☐ Valley

TOPO

2554
200
2354

17 Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
CRAGG DRILLING 111
Business name License No.
Address Rt 1 Dodge City Ks
Signed Larry D Cragg Date 10 sep 75
Authorized representative

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5