

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: COUNTY: FORD		Fraction NW 1/4 SW 1/4 SW 1/4	Section Number 32	Township Number T 26 S	Range Number R 25 E																																																										
Distance and direction from nearest town or city street address of well if located within city? 3 MILES WEST ON BEESON STREET, 1/4 MILES NORTH																																																															
2 WATER WELL OWNER: RR#, St. Address, Box #: ROUTE #1 City, State, ZIP code: DODGE CITY, KS 67801-		M. W. MCKIBBIN Board of Agriculture, Division of Water Resources Application Number:																																																													
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 185 ELEVATION: 0 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.																																																													
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width:5%; text-align:center;">1</td> <td style="width:10%; text-align:center;">NW</td> <td style="width:10%; text-align:center;">NE</td> <td style="width:10%;"></td> <td style="width:10%;"></td> <td style="width:10%;"></td> <td style="width:10%;"></td> <td style="width:10%;"></td> </tr> <tr> <td style="text-align:center;">W</td> <td></td> <td></td> <td></td> <td style="text-align:center;">E</td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align:center;">SW</td> <td></td> <td></td> <td></td> <td style="text-align:center;">SE</td> <td></td> <td></td> <td></td> </tr> <tr> <td style="text-align:center;">X</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		1	NW	NE						W				E				SW				SE				X								WELL'S STATIC WATER LEVEL 25 ft. below land surface measured on mo/day/yr 03/04/92 Pump testdata: Well water was 0 ft. after 0 hours pumping 0 gpm Estimated Yield 65 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm Bore Hole Diameter 10 in. to 185 ft., and in. to 0 ft. WELL WATER TO BE USED AS: DOMESTIC Was a chemical/bacteriological sample submitted to department? No ; If yes, mo/day/yr sample was submitted Water well disinfected? Yes																													
		1	NW	NE																																																											
		W				E																																																									
		SW				SE																																																									
X																																																															
5 TYPE OF BLANK CASING USED: PVC CASING JOINTS: GLUED Blank casing diameter 5 in. to 185 ft., Dia in. to 0 ft., Dia in. to 0 ft. Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. SAR 21 TYPE OF SCREEN OR PERFORATION MATERIAL: PVC SCREEN OR PERFORATION OPENINGS ARE: SAW CUT																																																															
SCREEN PERFORATED INTERVALS: GRAVEL PACK INTERVALS:																																																															
6 GROUT MATERIAL BENTONITE Grout intervals: From 5 ft. to 40 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft. What is the nearest source of possible contamination: SEPTIC TANK Direction from well? EAST How many feet? 75																																																															
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>4</td> <td>TOPSOIL</td> <td></td> <td></td> <td></td> </tr> <tr> <td>4</td> <td>45</td> <td>MEDIUM COARSE SAND</td> <td></td> <td></td> <td></td> </tr> <tr> <td>45</td> <td>80</td> <td>CLAY FINE SAND</td> <td></td> <td></td> <td></td> </tr> <tr> <td>80</td> <td>100</td> <td>CLAY MEDIUM SAND</td> <td></td> <td></td> <td></td> </tr> <tr> <td>100</td> <td>120</td> <td>MEDIUM COARSE SAND</td> <td></td> <td></td> <td></td> </tr> <tr> <td>120</td> <td>140</td> <td>COARSE SAND GRAVEL</td> <td></td> <td></td> <td></td> </tr> <tr> <td>140</td> <td>150</td> <td>CLAY FINE SAND</td> <td></td> <td></td> <td></td> </tr> <tr> <td>150</td> <td>185</td> <td>MEDIUM COARSE SAND</td> <td></td> <td></td> <td></td> </tr> <tr> <td>185</td> <td>200</td> <td>CLAY ROCK LAYER(S)</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>				FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	0	4	TOPSOIL				4	45	MEDIUM COARSE SAND				45	80	CLAY FINE SAND				80	100	CLAY MEDIUM SAND				100	120	MEDIUM COARSE SAND				120	140	COARSE SAND GRAVEL				140	150	CLAY FINE SAND				150	185	MEDIUM COARSE SAND				185	200	CLAY ROCK LAYER(S)			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																																																										
0	4	TOPSOIL																																																													
4	45	MEDIUM COARSE SAND																																																													
45	80	CLAY FINE SAND																																																													
80	100	CLAY MEDIUM SAND																																																													
100	120	MEDIUM COARSE SAND																																																													
120	140	COARSE SAND GRAVEL																																																													
140	150	CLAY FINE SAND																																																													
150	185	MEDIUM COARSE SAND																																																													
185	200	CLAY ROCK LAYER(S)																																																													
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 03/05/92 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 03/17/92 under the business name of JOE'S WELL SERVICE, INC. by (signature) <i>Joe's Well Service</i>																																																															