


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

South DODGE

BCD

1. Location of well:		County Ford	Fraction SE 1/4 SW 1/4 NW 1/4	Section number 32	Township number T 26 S	Range number R 25 E/W
2. Distance and direction from nearest town or city: 2 mi west, 1/2 north of Dodge City Street address of well location if in city:				3. Owner of well: Edith McClure R.R. or street: RFD 1 City, state, zip code: Dodge City, Kansas		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 28 in. Completion date waiting on design Well depth 192 ft. 8-15-76 pump		
				7. Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary		
5. Type and color of material		From To		8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other		
Surface		0 5		9. Casing: Material Metal Height: Above or below Threaded Welded X Surface 12 in. RMP PVC Weight 31.66 lbs./ft. Dia. 16 in. to 192 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gauge No. 188		
Coarse sand and gravel		5 31		10. Screen: Manufacturer's name W.A. Brown Type 10% Free-flow Dia. 16 Slot/gauze 1/8 Length 100 Set between 92 ft. and 192 ft. Gravel pack? yes Size range of material 1/2 down		
Clay		31 33		11. Static water level: 11 ft. below land surface Date 8-15-76 mo./day/yr.		
A-1 fine to half med. sand and gravel		33 45		12. Pumping level below land surfaces: 29 ft. after 1 hrs. pumping 700 g.p.m. 45 ft. after 1 hrs. pumping 1300 g.p.m. Estimated maximum yield 1500 g.p.m.		
Good med. sand & fine gravel with 10% clay		45 60		13. Water sample submitted: mo./day/yr. Yes X No Date		
Fine to half med. sand and fine gravel with 15% clay		60 84		14. Well head completion: Pitless adapter X Inches above grade		
Fine sand		84 90		15. Well grouted? Yes With: Neat cement Bentonite X Concrete Depth: From 0 ft. to 10 ft.		
Clay		90 93		16. Nearest source of possible contamination: ft. 2000 Direction north Type river Well disinfected upon completion? Yes X No		
Good fine to half med. sand and gravel		93 110		17. Pump: Not installed Manufacturer's name His used pump Model number HP Volts Length of drop pipe 50 ft. capacity g.p.m. Type: Submersible X Turbine Jet Reciprocating Centrifugal Other		
50% clay-50% fine sand		110 126		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name License No. Address Dodge City, Kansas Signed Paul B. [Signature] Date 11-15-76 Authorized representative		
Good A-1 coarse sand and gravel		126 175				
Good sand and gravel		175 187				
Gravel and fine sand with 15% clay		187 191				
Clay and blue shale		191 195				
B Rock 191						
(Use a second sheet if needed)						
18. Elevation:		19. Remarks: 180' sat there				
Topography: Hill Slope Upland X Valley		TOP 0 14 09 2502 191 2301				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5