

1 LOCATION OF WATER WELL		Fraction		Section Number		Township Number		Range Number	
County: Ford		SW $\frac{1}{4}$ SW $\frac{1}{4}$ SW $\frac{1}{4}$		32		T 26 S		R 25 E/W	
Distance and direction from nearest town or city? 3 3/4 mi west of Dodge City, Kansas					Street address of well if located within city?				
2 WATER WELL OWNER: Lowell A. Brakey									
RR#, St. Address, Box #: RR # 1					Board of Agriculture, Division of Water Resources				
City, State, ZIP Code: Dodge City, Kansas 67801					Application Number:				
3 DEPTH OF COMPLETED WELL: 165 ft. Bore Hole Diameter: 9 in. to 165 ft., and in. to ft.									
Well Water to be used as:									
<input checked="" type="checkbox"/> Domestic		3 Feedlot		5 Public water supply		8 Air conditioning		11 Injection well	
2 Irrigation		4 Industrial		6 Oil field water supply		9 Dewatering		12 Other (Specify below)	
7 Lawn and garden only		10 Observation well							
Well's static water level: 15 ft. below land surface measured on 4 month 30 day 1981 year									
Pump Test Data									
Est. Yield 25 gpm:		Well water was 20 ft. after 3 hours pumping 25 gpm							
4 TYPE OF BLANK CASING USED:									
1 Steel		3 RMP (SR)		5 Wrought iron		8 Concrete tile		Casing Joints: <u>Glued</u> Clamped	
2 PVC		4 ABS		6 Asbestos-Cement		9 Other (specify below)		<u>Welded</u> Threaded	
Blank casing dia 5 in. to 165 in.		Dia 12 in. to 165 in.		7 Fiberglass					
Casing height above land surface: in., weight 2.6 lbs./ft. Wall thickness or gauge No SDR 26									
TYPE OF SCREEN OR PERFORATION MATERIAL:									
1 Steel		3 Stainless steel		5 Fiberglass		7 PVC		10 Asbestos-cement	
2 Brass		4 Galvanized steel		6 Concrete tile		8 RMP (SR)		11 Other (specify)	
Screen or Perforation Openings Are:		5 Gauzed wrapped		8 Saw cut		11 None (open hole)			
1 Continuous slot		3 Mill slot		6 Wire wrapped		9 Drilled holes			
2 Louvered shutter		4 Key punched		7 Torch cut		10 Other (specify)			
Screen-Perforation Dia 5 in. to 30 ft., Dia in. to ft., Dia in. to ft.									
Screen-Perforated Intervals: From 135 ft. to 165 ft., From ft. to ft., From ft. to ft.									
Gravel Pack Intervals: From 13 ft. to 165 ft., From ft. to ft., From ft. to ft.									
5 GROUT MATERIAL:									
1 Neat cement		2 Cement grout		3 Bentonite		4 Other			
Grouted Intervals: From 3 ft. to 13 ft., From ft. to ft., From ft. to ft.									
What is the nearest source of possible contamination:									
1 Septic tank		4 Cess pool		7 Sewage lagoon		10 Fuel storage		14 Abandoned water well	
2 Sewer lines		5 Seepage pit		8 Feed yard		11 Fertilizer storage		15 Oil well/Gas well	
3 Lateral lines		6 Pit privy		9 Livestock pens		12 Insecticide storage		16 Other (specify below)	
Direction from well North How many feet 100 ? Water Well Disinfected? Yes <input checked="" type="checkbox"/> No									
Was a chemical/bacteriological sample submitted to Department? Yes No <input checked="" type="checkbox"/> If yes, date sample was submitted month day year: Pump Installed? Yes <input checked="" type="checkbox"/> No									
If Yes: Pump Manufacturer's name Reda Model No 14DL8P151 HP 1 1/2 Volts 220									
Depth of Pump Intake 105 ft. Pumps Capacity rated at 25 gal./min.									
Type of pump: 1 Submersible <input checked="" type="checkbox"/> 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other									
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on 5 month 4 day 1981 year									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 302									
This Water Well Record was completed on 5 month 6 day 1981 year under the business name of Hodde Drilling Co. by (signature) <i>Willie Hodde Jr.</i>									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:									
		FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG		
		0	3	Surface					
		3	15	Sandy clay					
		15	75	Sand and Gravel					
		75	90	Clay					
		90	105	Sand and Gravel					
		105	135	Clay					
135	165	Good Course sand and gravel							
165	170	Shale							
ELEVATION: Slope									
Depth(s) Groundwater Encountered 1. 15 ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)									

OFFICE USE ONLY

T

R

25

26

SEC

32

SW $\frac{1}{4}$ SW $\frac{1}{4}$ SW $\frac{1}{4}$

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.