

1 LOCATION OF WATER WELL		Fraction NW ¼ NW ¼ NW ¼		Section Number 34		Township Number T 26 S		Range Number R 25 E/W	
County: Ford				Distance and direction from nearest town or city?					
				Street address of well if located within city? West Park Street					
2 WATER WELL OWNER:		George Woolwine							
RR#, St. Address, Box # :		West Park Street							
City, State, ZIP Code :		Dodge City, Kansas 67801							
		Board of Agriculture, Division of Water Resources Application Number:							
3 DEPTH OF COMPLETED WELL		165 ft. Bore Hole Diameter 8 in. to ft., and in. to ft.							
Well Water to be used as:		5 Public water supply      8 Air conditioning      11 Injection well 1 Domestic      3 Feedlot      6 Oil field water supply      9 Dewatering      12 Other (Specify below) 2 Irrigation      4 Industrial      7 Lawn and garden only      10 Observation well							
Well's static water level		19 ft. below land surface measured on Dec. 3, 1979							
Pump Test Data		Well water was 19 ft. after 1 hours pumping 60 gpm							
Est. Yield 85 gpm		Well water was ft. after hours pumping gpm							
4 TYPE OF BLANK CASING USED:		5 Wrought iron      8 Concrete tile      Casing Joints: Glued <del>XXX</del> Clamped 1 Steel      3 RMP (SR)      6 Asbestos-Cement      9 Other (specify below)      Welded 2 PVC      4 ABS      7 Fiberglass           Threaded							
Blank casing dia 5 in. to 165 ft. Dia		in. to ft. Dia in. to ft.							
Casing height above land surface 12 in., weight		lbs./ft. Wall thickness or gauge No. 200 Jet stream							
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC      10 Asbestos-cement 1 Steel      3 Stainless steel      5 Fiberglass      8 RMP (SR)      11 Other (specify) 2 Brass      4 Galvanized steel      6 Concrete tile      9 ABS      12 None used (open hole)							
Screen or Perforation Openings Are:		5 Gauzed wrapped      8 Saw cut      11 None (open hole) 1 Continuous slot      3 Mill slot      6 Wire wrapped      9 Drilled holes 2 Louvered shutter      4 Key punched      7 Torch cut      10 Other (specify)							
Screen-Perforation Dia 1/8 in. to 20 ft. Dia		in. to ft. Dia in. to ft.							
Screen-Perforated Intervals:		From 140 ft. to 160 ft.      From ft. to ft.      From ft. to ft. From ft. to ft.      From ft. to ft.      From ft. to ft.							
Gravel Pack Intervals:		From 50 ft. to 165 ft.      From ft. to ft.      From ft. to ft. From ft. to ft.      From ft. to ft.      From ft. to ft.							
5 GROUT MATERIAL:		1 Neat cement      2 Cement grout      3 Bentonite      4 Other							
Grouted Intervals: From 10 ft. to 50 ft.		ft. From ft. to ft.							
What is the nearest source of possible contamination:		10 Fuel storage      14 Abandoned water well 1 Septic tank      4 Cess pool      7 Sewage lagoon      11 Fertilizer storage      15 Oil well/Gas well 2 Sewer lines      5 Seepage pit      8 Feed yard      12 Insecticide storage      16 Other (specify below) 3 Lateral lines      6 Pit privy      9 Livestock pens      13 Watertight sewer lines							
Direction from well West		How many feet 85 ? Water Well Disinfected? Yes <del>XXX</del> No							
Was a chemical/bacteriological sample submitted to Department? Yes		No <del>XXX</del> If yes, date sample was submitted month day year							
If Yes: Pump Manufacturer's name Goulds		Model No. 13EM HP 1 Volts 230							
Depth of Pump Intake 84 ft.		Pumps Capacity rated at 13 gal./min.							
Type of pump: 1 Submersible		2 Turbine      3 Jet      4 Centrifugal      5 Reciprocating      6 Other							
6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on Dec. 5, 1979									
and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179									
This Water Well Record was completed on Feb. 19, 1980									
name of Joe's Well Service Cimarron, Ks. by (signature) Larry Crick									
7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		FROM TO		LITHOLOGIC LOG		FROM TO		LITHOLOGIC LOG	
		0 15		Top soil, clay & fine to coarse sand					
		15 30		Coarse sand & clay					
		30 45		Clay					
		45 90		Clay & fine sand layers					
		90 105		Clay & medium to coarse sand					
		105 135		Medium to coarse sand					
		135 150		Medium to coarse sand & clay (2ft.)				Bick 165	
		150 165		Medium to coarse sand				146 to 146.5	
165 180		Clay & blue shale							
ELEVATION:		11 y						2558	
Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft. 4. ft. (Use a second sheet if needed)									

OFFICE USE ONLY

T

26

R

25

EW

SEC.

34

NW ¼

NW ¼

NW ¼

NW ¼