

## CORRECTION(S) TO WATER WELL RECORD (WWC-5)

(to rectify lacking or incorrect information)

County: Ford

Location listed as:

Section-Township-Range: 31-26-25EFraction (  $\frac{1}{4}$   $\frac{1}{4}$   $\frac{1}{4}$  ): SW SE SW

Location changed to:

31-26-25WSW SE SW

Other changes: Initial statements: \_\_\_\_\_

Changed to: \_\_\_\_\_

Comments: E changed to Wverification method: County maps, location and address informationinitials: ms date: 3-3-06

submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726  
to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

1 LOCATION OF WATER WELL: Fraction Section Number Township Number Range Number  
 COUNTY: FORD SW 1/4 SE 1/4 SW 1/4 31 T 26 S R 25 E

Distance and direction from nearest town or city street address of well if located within city?

DODGE CITY - ON MARSHALL ROAD 4 MILES WEST

2 WATER WELL OWNER: CUMMING, DON  
 RR#, St. Address, Box #: 10620 MARSHALL ROAD Board of Agriculture, Division of Water Resources  
 City, State, ZIP code: DODGE CITY, KS 67801- Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

N				
	---	NW	---	NE
W				
	---		---	E
		SW		SE

4 DEPTH OF COMPLETED WELL 185 ELEVATION: 0  
 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.

WELL'S STATIC WATER LEVEL 62 ft. below land surface measured on mo/day/yr 07/08/05  
 Pump test data: Well water was 0 ft. after 0 hours pumping 0 gpm

Estimated Yield 50 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm

Bore Hole Diameter 10 in. to 185 ft., and in. to 0 ft.

WELL WATER TO BE USED AS: DOMESTIC

Was a chemical/bacteriological sample submitted to department? No ;  
 If yes, mo/day/yr sample was submitted Water well disinfected? Yes

5 TYPE OF BLANK CASING USED: PVC CASING JOINTS: GLUED  
 Blank casing diameter 5 in. to 185 ft., Dia in. to 0 ft., Dia in. to 0 ft.  
 Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21  
 TYPE OF SCREEN OR PERFORATION MATERIAL: PVC  
 SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 120 ft. to 180 ft., From 0 ft. to 0 ft.  
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.  
 GRAVEL PACK INTERVALS: From 25 ft. to 185 ft., From 0 ft. to 0 ft.  
 From 0 ft. to 0 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE  
 Grout Intervals: From 5 ft. to 25 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft.  
 What is the nearest source of possible contamination: NONE  
 Direction from well? How many feet? 0

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	20	01 TOPSOIL 37 FIN-COAR SAN 09 GRAVEL			
20	80	37 FIN-COAR SAN 09 GRAVEL 06 SMALL GRAVEL			
80	100	37 FIN-COAR SAN 05 CLAY 02 FINE SAND			
100	140	37 FIN-COAR SAN 06 SMALL GRAVEL			
140	160	37 FIN-COAR SAN 06 SMALL GRAVEL 05 CLAY			
160	180	05 CLAY 37 FIN-COAR SAN 05 CLAY			
180	195	05 CLAY 07 BLUE SHALE			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 07/11/05 and this record is true to the best of my knowledge and belief. Kansas  
 Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 07/30/05  
 under the business name of JOE'S WELL SERVICE, INC. by (signature) *Quaid Creek*