

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

DDD

1. Location of well:		County Ford	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 24	Township number T 26	Range number S R 25 X/W
2. Distance and direction from nearest town or city: 2 miles east of 14th street on highway 50 bypass and 1/2 mile south. Street address of well location if in city:			3. Owner of well: Andy Kindswater R.R. or street: 2212 4th Ave. City, state, zip code: Dodge City, Kansas 67801			
4. Locate with "X" in section below: Sketch map: N 1 Mile W E S 1 Mile			6. Bore hole dia. <u>8</u> in. Completion date _____ Well depth <u>240</u> ft. <u>3-17-77</u>			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
<p style="text-align: center;">Pasture well</p>			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
5. Type and color of material			9. Casing: Material <u>RMP</u> Height: Above or Below _____ Threaded _____ Welded _____ Surface <u>12</u> in. RMP <u>XX</u> PVC _____ Weight _____ lbs./ft. Dia. <u>65/8</u> in. to <u>240</u> ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. <u>250</u>			
			10. Screen: Manufacturer's name _____ Jess & Lowell Type <u>RMP</u> Dia. <u>65/8"</u> Slot 2/32 <u>1/8"</u> Length <u>20ft.</u> Set between <u>205</u> ft. and <u>235</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/4"</u>			
			11. Static water level: _____ mo./day/yr. <u>127</u> ft. below land surface Date <u>3-17-77</u>			
			12. Pumping level below land surfaces: <u>140</u> ft. after <u>1</u> hrs. pumping <u>48</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>90</u> g.p.m.			
			13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
			14. Well head completion: <u>None</u> <input type="checkbox"/> Pitless adapter _____ Inches above grade			
			15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.			
			16. Nearest source of possible contamination: <u>none</u> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <u>XX</u> Yes <input type="checkbox"/> No			
			17. Pump: <u>Windmill</u> <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Joe's Well Service <u>179</u> Business name License No. Address <u>Box 174 Cimarron, Ka.</u> Signed <u>Jay Crick</u> Date <u>3-18-77</u> Authorized representative		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<p style="text-align: center;">(Use a second sheet if needed)</p> <p style="text-align: center;"><u>127</u></p>		<p style="text-align: center;"><u>113 sat thick</u></p> <p style="text-align: center;"><u>240</u></p>		

26
 25
 24
 SESESE
 1/4 1/4 1/4