

| | | | | | |
|---------------------------|--|----------------------|----------------|-----------------|----------------|
| 1 LOCATION OF WATER WELL: | | Fraction | Section Number | Township Number | Range Number |
| COUNTY: FORD | | SW 1/4 NW 1/4 SW 1/4 | 16 | T 26 S | R 26 <i>EW</i> |

Distance and direction from nearest town or city street address of well if located within city?
 10884 102 ROAD HOWELL, KS 67801-

| | | |
|--|--|---|
| 2 WATER WELL OWNER: DODGE CITY COOPERATIVE | | Board of Agriculture, Division of Water Resources |
| RR#, St. Address, Box #: 10884 102 ROAD | | Application Number: |
| City, State, ZIP code: HOWELL, KS 67801- | | |

| | | | | | | | | | | | | |
|--|--|--|----|----|---|--|--|----|--|----|---|--|
| 3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: | | 4 DEPTH OF COMPLETED WELL 185 ELEVATION: 0 | | | | | | | | | | |
| <div style="display: flex; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg); margin-right: 5px;">1 mile</div> <table border="1" style="border-collapse: collapse; text-align: center;"> <tr><td></td><td>NW</td><td>NE</td></tr> <tr><td>X</td><td></td><td></td></tr> <tr><td>SW</td><td></td><td>SE</td></tr> </table> </div> | | | NW | NE | X | | | SW | | SE | Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft. | |
| | | | NW | NE | | | | | | | | |
| | | X | | | | | | | | | | |
| | | SW | | SE | | | | | | | | |
| | | WELL'S STATIC WATER LEVEL 35 ft. below land surface measured on mo/day/yr 07/05/95 | | | | | | | | | | |
| Pump test data: Well water was 0 ft. after 0 hours pumping 0 gpm | | | | | | | | | | | | |
| Estimated Yield 60 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm | | | | | | | | | | | | |
| | | Bore Hole Diameter 9 in. to 185 ft., and in. to 0 ft. | | | | | | | | | | |
| | | WELL WATER TO BE USED AS: DOMESTIC | | | | | | | | | | |
| | | Was a chemical/bacteriological sample submitted to department? No ; | | | | | | | | | | |
| | | If yes, mo/day/yr sample was submitted Water well disinfected? Yes | | | | | | | | | | |

| | | | |
|--|--|--|--|
| 5 TYPE OF BLANK CASING USED: PVC | | CASING JOINTS: GLUED | |
| Blank casing diameter 5 in. to 185 ft., Dia in. to 0 ft., Dia in. to 0 ft. | | | |
| Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21 | | | |
| TYPE OF SCREEN OR PERFORATION MATERIAL: PVC | | | |
| SCREEN OR PERFORATION OPENINGS ARE: SAW CUT | | | |
| SCREEN PERFORATED INTERVALS: | | From 150 ft. to 180 ft., From 0 ft. to 0 ft. | |
| GRAVEL PACK INTERVALS: | | From 0 ft. to 0 ft., From 0 ft. to 0 ft. | |
| | | From 40 ft. to 185 ft., From 0 ft. to 0 ft. | |
| | | From 0 ft. to 0 ft., From 0 ft. to 0 ft. | |

| | |
|---|-------------------|
| 6 GROUT MATERIAL BENTONITE | |
| Grout Intervals: From 0 ft. to 40 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft. | |
| What is the nearest source of possible contamination: WATERTIGHT SEW. | |
| Direction from well? NORTH | How many feet? 70 |

| FROM | TO | LITHOLOGIC LOG | FROM | TO | PLUGGING INTERVALS |
|------|-----|----------------------|------|----|--------------------|
| 0 | 5 | TOPSOIL SANDY CLAY | | | |
| 5 | 27 | MEDIUM SAND GRAVEL | | | |
| 27 | 40 | BROWN CLAY | | | |
| 40 | 52 | SAND GRAVEL | | | |
| 52 | 60 | YELLOW CLAY | | | |
| 60 | 70 | CLAY FINE SAND | | | |
| 70 | 142 | FINE SAND SANDY CLAY | | | |
| 142 | 180 | MEDIUM SAND GRAVEL | | | |
| 180 | 200 | BLUE SHALE | | | |

| | |
|--|--|
| 7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 07/07/95 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 08/02/95 under the business name of JOB'S WELL SERVICE, INC. by (signature) <i>James Creek</i> | |
|--|--|